



To: **Planning Reps**
From **Highways Development Management Officer**

Date 4th November 2021

Your Ref 20211361

Location Courtlands Gravesend Road Shorne Gravesend Kent DA12 3JR

I have no objections to the proposal, a four bedroom dwelling is replaced with a three bedroom one and the existing access remains unaltered. There will be sufficient space on the drive to comply with car parking requirements.

It is suggested that as this is a new build, the applicant should make appropriate provision for the charging of electric vehicles, which at a minimum would be providing the cables necessary to support a minimum of two charging points each capable of accommodating a minimum continuous supply (more under surge demand) of 7kW

Les Seaborn
Highways Development Management Officer

