


Environmental Protection COMMENTS

Case Number	20231319
Case Officer	Ms Lisa Williams
Address	St Josephs Convent Of Mercy, Hillside Drive, Gravesend, Kent, DA12 1NY
Proposal	Alterations to the convent to include; proposed installation of new entrance at Theydon, closing of the party wall between Theydon and Hillside, extension to the staircase, alterations to the existing 1950s block to include cladding, re-glazing and re-roofing. Addition of a first floor to the chapel with roof lights and re-ordering of rooms and new lift.
Consultation Expiry Date	2 February 2024
Date of Response	18 January 2024 (JO)

No objection to this application. The following to be considered:

Code of Practice on Construction and Demolition:



Please apply as appropriate to minimise the impact on the conversion/construction works on the area.

Asbestos:

Prior to any alterations to the existing buildings an appropriate Asbestos survey of the buildings should be undertaken and a scheme implemented to remove and safely dispose of any asbestos-containing materials in accordance with the Control of Asbestos Regulations 2012 and the applicant's/developer's Waste duty of care.