

Shorne Parish Council

————— Borough of Gravesham —————

Clerk & Responsible Officer
Shorne Village Hall
The Street
Shorne
Nr Gravesend
Kent DA12 3EA

E-mail: clerk@shorneparishcouncil.org



24th November 2025

Application ref 20251148

1 Pipes Place Forge Lane Shorne Gravesend Kent DA12 3DP

**The Electronic Communications Code (Conditions and restrictions) Regulations 2003 (as amended)
- Regulation 5 Notice of Intention to Install Fixed Line Broadband Apparatus; 10 metre pole.**

The Parish Council has no objection in principle to this application.

The proposed location is difficult to determine exactly as the telephone manhole covers do not seem to be in quite the same positions as shown on the plans.

The location is in the Shorne Village Conservation Area and affects the setting of two Listed buildings. It should be noted that the garden wall of Pipes Place is also Listed Grade II in its own right as it dates from the 1700's, damage must be avoided. Specialist advice might be appropriate.

The location is close to important mature trees and where the footway and verge are very narrow, adverse impacts on these and the footings and stability of the wall should be considered, and more detail of required mitigation provided.

We would be very grateful if these matters could be drawn to the Applicant's attention.