

Location	Requirement					Fitting	Results			
	Illuminance (lx)	Efficacy (lm/W)	Uniformity (min)	Uniformity (Pref.)	Em _{Min} (lx)		Illuminance (lx)	Efficacy (lm/W)	Uniformity (U0/g ₁)	Em _{Min} (lx)
External										
Path	5	95	0.25	0.4	1	EX1 - SSUK PF/25W/DOM/B-01	22	95	0.1	N/A
Car Park	10	95	0.25	0.25		EX1 - SSUK PF/25W/DOM/B-01	15	95	0.1	N/A
Escape Route Path	10	95	0.25	0.4	1	EX1 - SSUK PF/25W/DOM/B-01	28	95	0.06	N/A
Ent and Seating area	10	95	0.25	0.4		EX1 - SSUK PF/25W/DOM/B-01	30	95	0.1	N/A