

Delegated Report

Lawful Development Certificate (Proposed)

Application no:	20230419
Location	7 The Turnstones Gravesend Kent DA12 5QD
Proposal:	Application for a Lawful Development Certificate in respect of the proposed erection of a single storey rear and side extension, erection of entrance canopy.
Applicant:	Mr Sukhdeep Randhawa
Site Visit	N/A Desktop Assessment

Plans & Documents

Application form
 Drawing no. TT/001 (site location plan)
 Drawing no. TT/002 (existing site plan)
 Drawing no. TT/303 rev A (proposed site plan)
 Drawing no. TT/401 (proposed plans)
 Drawing no. TT/301 (existing plans)

Property Type

The property comprises a detached single storey dwelling.

Material Consideration

Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended)

Relevant Planning History

20230072	Application for a Lawful Development Certificate in respect of the proposed erection of a single storey rear and side extension, erection of entrance canopy	Refused	14.03.2023
19840393	Erection of 100 dwellings with car parking and garages associated earthworks and laying out of access road onto Hillside Avenue and Old Road East	Permitted	22.11.1984

Officer Assessment

Permitted Developments Rights Restrictions

Article 2 (3) Land (AONB, Conservation Area)	N
Article 4 Direction	N
Permitted Development Rights Removed/Restricted	Y (reserved parking condition)

Class A - The enlargement, improvement or other alteration of a dwellinghouse

A.1	Development is not permitted by Class A if –	Y/N
(a)	permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use)	N
(b)	as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse)	N
(c)	the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse	N
(d)	the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse	N
(e)	the enlarged part of the dwellinghouse would extend beyond a wall which – (i) forms the principal elevation of the original dwellinghouse; or (ii) fronts a highway and forms a side elevation of the original dwellinghouse	Y (but this is a porch/canopy dealt with under Class D below)
(f)	subject to paragraph (g), the enlarged part of the dwellinghouse would have a single storey and - (i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height	N
(g)	for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and - (i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height;	N/A
(h)	the enlarged part of the dwellinghouse would have more than a single storey and – (i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or (ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;	N/A

(i)	the enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres	N
(j)	the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would – (i) exceed 4 metres in height, (ii) have more than a single storey, or (iii) have a width greater than half the width of the original dwelling; or	Y(i) – approx. 4.8m
(ja)	any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j);	N
(k)	it would consist of or include – (i) the construction or provision of a verandah, balcony or raised platform, (ii) the installation, alteration or replacement of a microwave antenna, (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or (iv) an alteration to any part of the roof of the dwellinghouse	N
(l)	the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses)	N
A.2	In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if –	N/A
(a)	it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;	
(b)	the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or	
(c)	the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.	
(d)	any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c).	
A.3	Development is permitted by Class A subject to the following conditions –	N/A
(a)	the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;	
(b)	any upper-floor window located in a wall or roof slope forming a side elevation of	

	the dwellinghouse must be – (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and	
(c)	where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.	

Class D - The erection or construction of a porch outside any external door of a dwellinghouse.

D.1	Development is not permitted by Class D if -	Y/N
(a)	permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use)	N
(b)	The ground area (measured externally) of the structure would exceed 3 square metres	Y (3.3sqm – the measurements shown on the plans are not external)
(c)	Any part of the structure would be more than 3 metres above ground level; or	Y (3.3sqm)
(d)	Any part of the structure would be within 2 metres of any boundary of the curtilage of the dwellinghouse with a highway; or	N
(e)	the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses)	N
D.1	Development is not permitted by Class D if -	
(a)	permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use)	N
(b)	The ground area (measured externally) of the structure would exceed 3 square metres	Y (see above)

Recommendation: Refuse Lawful Development Certificate

Case Officer:	Mrs Alison Webster	Team Leader:	Miss Faye Hobbs
Signed:		Signed:	

Dated:	12th June 2023	Dated:	14 June 2023
---------------	----------------	---------------	--------------