



To: **Planning Reps**
From **Highways Development Management Officer**

Date 17th May 2023

Your Ref 20230362

Location 39 The Terrace, Gravesend, Kent

I have no objections to the proposal but am concerned about the intention to open up light wells within the public highway to provide light to the occupied basements. Whilst it appears there may be two existing light wells two new ones would have to be constructed and this would require Kent County Council's approval and in particular technical approval if permitted to ensure the support of the highway is not compromised. This is a matter than can only be resolved with Kent County Council as Highway Authority and could be a lengthy and costly business

Les Seaborn
Highway Development Management Officer

