



Delegated Report

Lawful Development Certificate (Proposed)

Application no:	20220700
Location	17 Westfield Close Gravesend Kent DA12 5EH
Proposal:	Application for a Lawful Development Certificate in respect of the proposed construction of an outbuilding for use of the main dwelling.
Applicant:	Mr Rishi Upple
Site Visit	N/A Desktop Assessment

Plans & Documents

Application Form Dated 24/06/2022;
Supplementary Information – Statement of Evidence;
Drawing No D06 (Block Plans – Existing and Proposed with Site Location Plan);
Drawing No D07 (Elevations and Floor Plans – Existing); and
Drawing No D08 (Elevations and Floor Plans – Proposed).

Property Type

17 Westfield Close is a two-storey semi-detached dwellinghouse.

Material Consideration

Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended)

Relevant Planning History

Application No.	Description	Status	Decision
19750058	Erection of a single storey rear extension for kitchen and lounge	Permitted	26.03.1975

Officer Assessment

Permitted Developments Rights Restrictions

Article 2 (3) Land (AONB, Conservation Area)	N
Article 4 Direction	N
Permitted Development Rights Removed/Restricted	N

Class E - The provision within the curtilage of the dwellinghouse of –

(a) any building or enclosure, swimming or other pool required for a purpose incidental to the enjoyment of the dwellinghouse as such, or the maintenance, improvement or other alteration of such a building or enclosure; or

(b) a container used for domestic heating purposes for the storage of oil or liquid petroleum gas.

E.1	Development is not permitted by Class E if –	Y/N
(a)	Permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use);	N
(b)	The total area of ground covered by building, enclosures and containers within the curtilage (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse);	N
(c)	Any part of the building, enclosure, pool or container would be situated on land forward of a wall forming the principal elevation of the original dwellinghouse;	N
(d)	The building would have more than a single storey;	N
(e)	The height of the building, enclosure or container would exceed – (i) 4 metres in the case of a building with a dual-pitched roof, (ii) 2.5 metres in the case of a building, enclosure or container within 2 metres of the boundary of the curtilage of dwellinghouse, or (iii) 3 metres in any other case;	N/A N 2.5m N/A
(f)	The height of the eaves of the building would exceed 2.5 metres;	N
(g)	The building, enclosure, pool or container would be situated within the curtilage of a listed building;	N
(h)	It would include the construction or provision of a verandah, balcony or raised platform;	N
(i)	It relates to a dwelling or a microwave antenna; or	N
(j)	The capacity of the container would exceed 3,500 litres	N/A
(k)	the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses)	N
E.2	In the case of any land within the curtilage of a dwellinghouse which is within – (a) An area of outstanding natural beauty; Development is not permitted by Class E if the total area of ground covered by buildings, enclosures, pools and containers situated more than 20 metres from any wall of the dwellinghouse would exceed 10 square metres.	N/A

E.3	In the case of any land within the curtilage of the dwellinghouse which is article 2(3) land, development is not permitted by Class E if any part of the building, enclosure, pool or container would be situated on land between a wall forming a side elevation of the dwellinghouse and the boundary of the curtilage of the dwellinghouse.	N/A
------------	--	-----

Conclusion

The proposed development complies with Schedule 2, Part 1, Class E of **THE TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) (ENGLAND) ORDER 2015, AS AMENDED**, and the **LAWFUL DEVELOPMENT CERTIFICATE is GRANTED.**

Recommendation: Grant Lawful Development Certificate

Case Officer:	Mrs Nina Goodbody	Team Leader:	Miss Faye Hobbs
Signed:	<i>N Goodbody</i>	Signed:	
Dated:	17 th August 2022	Dated:	17 August 2022