



Head of Planning & Regeneration Services
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Your ref
20240199

Our ref
DSA000033348

Date
02 May 2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Erection of a new three storey office building, for use class E and installation of solar panels to roof. Erection of a single storey storage building with integral roof lights, for use class B8 and associated parking and landscaping.

Site: 20240199: - Dalefield Industrial Park, Dalefield Way, Gravesend, Kent, DA12 2FL.

Thank you for your letter dated 11 April 2024.

Following the review of the submitted documents, we have the below comments for the Planning consultation.

Wastewater Treatment Works Proximity

In determining the application, we ask that the Planning Authority take into account the provisions of Paragraphs 180, 182 and 183 of the National Planning Policy Framework (NPPF) regarding the proposed location of development in relation to existing uses that may be a source of pollution (in terms of odour). We apply a precautionary buffer zone for any development located within 500 metres of the boundary of a WWTW. The proposed development is located approximately 220 metres from the Gravesend Wastewater Treatment Works, and as such we have applied this requirement to our planning consultation response. Please contact Southern Water to discuss and agree the Scope of the odour assessment.

Due to the potential odour nuisance from a Wastewater Treatment Works, no sensitive development should be located within the 1.5 OdU odour contour of the WWTW. An Odour Assessment will need to be carried out by a specialist consultant employed by the developer to a specification that will need to be agreed in advance with Southern Water to identify and agree the 1.5 OdU contour. The service we provide to review the assessment and/or complete a site survey is chargeable, more information regarding our fees can be found on our website; Connection charging arrangements ([Connecting Charging Arrangements - Southern Water](#)).

Foul and Surface Water Drainage

Our investigations indicate that Southern Water can facilitate foul sewerage disposal to service the proposed development. Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

The Council's technical staff and the relevant authority for land drainage consent should comment on the adequacy of the proposals to discharge surface water to the local watercourse.

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by the Local Planning Authority in consultation with Southern Water.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development