

20231313 Eastcourt Marshes Electricity Distribution Site

Kent Fire and Rescue 20 September 2024

Although the Gravesend Headhouse - Planning - Site Plan PDD-100116-LAY-053 Rev P03 does appear to show access roads to and within the site with dimensions at or above the required 3.7m, and that access roads are either stone surfaced, or tarmac surfaced. Please ensure these roads have the minimum carrying capacity for our pump appliances meeting the typical fire and rescues service vehicle access route specification.

The above plans also show turning facilities at the end of the new maintenance road adjacent to the Headhouse. Please confirm the Headhouse can be reached from this area from a suitable route for laying hose.