



Metres

0 1.0 2.0



Flat 6 (< 5 m ² /(h.m ²) at 50 Pa					
Dwelling Details					
Floor Area	69.90 m ²		Whole building ventilation rate		
Room Height	2.40 m		Default	17/s	
Volume	167.76 m ³		0.3l/s per m ²	21/s	
Bedrooms	2				
Additional Occupants	0		Minimum ventilation rate	21/s	
<u>Extract Normal Speed</u>			<u>Supply Normal Speed (Positive Pressure)</u>		
Kitchen	13l/s		Living/Dining	10l/s	
Bathroom	8l/s		Bedroom 1	7l/s	
			Bedroom 2	6l/s	
Total Airflow	21l/s		Total Airflow	23l/s	
<u>Extract Boost Speed</u>			<u>Supply Boost Speed (Positive Pressure)</u>		
Kitchen	14l/s		Living/Dining	11l/s	
Bathroom	9l/s		Bedroom 1	8l/s	
			Bedroom 2	7l/s	
Total Airflow	23l/s		Total Airflow	26l/s	



DATE 04/06/2021

ZEHNDER GROUP UK Ltd, CONCEPT HOUSE, WATCHMOOR POINT, CAMBERLEY, SURREY, GU15 3AD TELEPHONE : (01276) 408403.