

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 07/04/2025 12:35 AM from Planning Consents.

Application Summary

Address:	53 Villa Road Higham Rochester Kent ME3 7BU
Proposal:	Demolition of existing structures and erection of 3 bungalows.
Case Officer:	Mrs Lisa Fisher

[Click for further information](#)

Customer Details

Name:	Planning Consents
Email:	planningconsents@ukpowernetworks.co.uk
Address:	UK Power Networks, Barton Road BURY ST. EDMUNDS

Comments Details

Commenter Type:	Consultee
Stance:	Customer made comments neither objecting to or supporting the Planning Application

Reasons for comment:

Comments: We note there are overhead cables running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

In the instance of overhead cables within the vicinity, GS6 (Advice on working near overhead powerlines) and a safety visit is required by UK Power Networks. Information and applications regarding GS6 can be found on our website <https://www.ukpowernetworks.co.uk/safety-equipment/power-lines/working-near-power-lines/advice-on-working-near-overhead-power-lines-gs6#Apply>

Should any diversion works be necessary because of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

You can also find support and application forms on our website [Moving electricity supplies or equipment | UK Power Networks](#)

Kind regards