

20221183 Joynes House New Road

HASEXF - Health And Safety Executive - Fire Safety 27 March 2023

Thank you for your email in relation to the above application.

HSE is the statutory consultee for planning applications that involve or may involve a relevant building.

Relevant building is defined as:

- contains two or more dwellings or educational accommodation and
- meets the height condition of 18m or more in height, or 7 or more storeys

“Dwellings” includes flats, and “educational accommodation” means residential accommodation for the use of students boarding at a boarding school or in later stages of education (for definitions see article 9A (9) of the Town and Country Planning Development Management (England) Procedure Order 2015 as amended by article 4 of the 2021 Order.

However, from the information you have provided for this planning application, it does not appear to fall under the remit of planning gateway one because it does not meet the height requirement.

Further information is available on the HSE website [here](#).

Once again thank you for your email, if you require further advice with regards to this application, please do not hesitate to contact the planning gateway one team quoting our reference number (pgo-3037) in all future correspondence