

Delegated Report

Lawful Development Certificate (Proposed)

Application no:	20220872
Location	92 Ferndale Road Gravesend Kent DA12 5AE
Proposal:	Application for a Lawful Development Certificate in respect of the proposed erection of a single storey rear extension including a lantern light and bi-folding doors.
Applicant:	Mr Watson, Phoenix Brickwork
Site Visit	Desktop Assessment

Preliminary Matters

The agent was emailed on 11.10.22 to query whether the proposed external materials for the extension would be similar to the existing, in order to comply with A.3 (a) of the Town and Country Planning (General Permitted Development) (England) Order 2015, as amended.

The agent confirmed the above on 11.10.22.

Plans & Documents

Application Form;
 Supplementary Information – Agent email confirming proposed materials will be similar to the existing (received 11.10.22);
 Block Plan – Proposed (received 12.09.22);
 OS Plan (received 12.09.22);
 Front Elevation – Proposed (received 12.09.22);
 Side Elevation – Proposed (received 12.09.22);
 Side Elevation (2) – Proposed (received 12.09.22);
 Rear Elevation – Proposed (received 12.09.22);
 Isometric View of Proposal (received 12.09.22);
 Front elevation – Existing (received 12.09.22);
 Side Elevation – Existing (received 12.09.22);
 Side Elevation (2) – Existing (received 12.09.22);
 Rear Elevation – Existing (received 12.09.22);
 Isometric View of Existing (received 12.09.22);
 Floor Plan as Existing (received 02.09.22); and
 Floor Plan as Proposed (received 02.09.22).

Property Type

92 Ferndale Road is a two storey semi-detached property.

Material Consideration

Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended)

Relevant Planning History

No relevant history.

Officer Assessment*Permitted Developments Rights Restrictions*

Article 2 (3) Land (AONB, Conservation Area)	N
Article 4 Direction	N
Permitted Development Rights Removed/Restricted	N

Class A - The enlargement, improvement or other alteration of a dwellinghouse

A.1	Development is not permitted by Class A if –	Y/N
(a)	permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use)	N
(b)	as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse)	N
(c)	the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse	N
(d)	the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse	N
(e)	the enlarged part of the dwellinghouse would extend beyond a wall which – (i) forms the principal elevation of the original dwellinghouse; or (ii) fronts a highway and forms a side elevation of the original dwellinghouse	N N
(f)	subject to paragraph (g), the enlarged part of the dwellinghouse would have a single storey and - (i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height	N 3.00m N 3.02m (inclusive of roof lantern)
(g)	for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and -	

	(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height;	N/A
(h)	the enlarged part of the dwellinghouse would have more than a single storey and – (i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or (ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;	N/A N/A
(i)	the enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres	N Eaves are 2.52m
(j)	the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would – (i) exceed 4 metres in height, (ii) have more than a single storey, or (iii) have a width greater than half the width of the original dwelling; or	N/A
(ja)	any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j);	N/A Existing conservatory to be demolished
(k)	it would consist of or include – (i) the construction or provision of a verandah, balcony or raised platform, (ii) the installation, alteration or replacement of a microwave antenna, (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or (iv) an alteration to any part of the roof of the dwellinghouse	N N N N
(l)	the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses)	N
A.2	In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if –	Y/N
(a)	it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;	N/A
(b)	the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or	N/A

(c)	the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.	N/A
(d)	any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c).	N/A
A.3	Development is permitted by Class A subject to the following conditions –	Y/N
(a)	the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;	Y As per email received 11.10.22
(b)	any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be – (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and	N/A
(c)	where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.	N/A

Conclusion

The proposed development complies with Schedule 2, Part 1, Class A of **THE TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) (ENGLAND) ORDER 2015, AS AMENDED**, and the **LAWFUL DEVELOPMENT CERTIFICATE is GRANTED.**

Recommendation: Grant Lawful Development Certificate

Case Officer:	Mrs Lucy Hankin	Team Leader:	Miss Faye Hobbs
Signed:	L Hankin	Signed:	
Dated:	21 st October 2022	Dated:	21 October 2021