



Alison Webster
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Flood and Water Management
Invicta House
Maidstone
Kent
ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: GBC/2024/102701
Date: 17 February 2025

Application No: 20240970

Location: Bowling Green , Church Walk, Gravesend, Kent DA12 2QU

Proposal: Application for variation of Condition 2 (Approved Plans) attached to planning permission reference number 20221328 for demolition of existing bowls pavilion and erection of a 4-storey building to provide a 62-unit Use Class C2 retirement living complex, with a new access from Ellerslie, a new emergency access off Ellerslie, parking, landscaping and associated works; to allow substation repositioned to southeastern corner of site, now accessed from Church Walk. Projecting units in central portion of eastern elevation to Church Walk aligned / projection removed, replaced with brick details. Opaque balustrades to balconies replaced with glazed panels. Some window depths and location of transoms altered to improve proportions.

Thank you for your consultation on the above referenced planning application.

Kent County Council as Lead Local Flood Authority have received additional information from the applicant and have the following comments:

- It can be noted that updated hydraulic calculations have been provided demonstrating the drainage scheme will not be adversely affected by the amendments to the drainage strategy.

Kent County Council as Lead Local Flood Authority would see no further reason to object to the variation of Condition 2.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

Euan Allen
Graduate Flood Risk Officer
Flood and Water Management