
From: Pisarczykowski, Piotr
Sent: 03 September 2021 15:06
To: Planning Admin
Cc: Bonthron, Ethan
Subject: Planning Application Consultation for application 20210993 Morrison's
Attachments: Coldharbour Road, Morrisons Ref 20210993 - EP Comments - PP.doc

Dear All

Please find attached our comments in relation to Planning Application: 20210993

Kind Regards
Piotr

Piotr Pisarczykowski BSc (Hons)
Environmental Health Technician
Gravesham Borough Council
Email: piotr.pisarczykowski@gravesham.gov.uk

Gravesham Borough Council - Delivering a Gravesham to be proud of

**INVESTORS
IN PEOPLE**



HANDS



FACE



SPACE

Gravesham
Borough Council



Environmental Protection COMMENTS

Case Number	20210993
Case Officer	Mr Ethan Bonthron
Address	Morrisons, Coldharbour Road, Northfleet, Gravesend Kent
Proposal	Removal of existing refrigeration condensers and redundant A/C mechanical plant on main store roof and installation of 2no. CO2 energy efficient plant of similar size to main store roof, installation of 3no. new Load cells for new CO2 energy efficient plant and installation of new Heat Pump pack.
Date of Response	03/09/2021

We have no objection subject to the following comments. If permission is given, we would ask that the following conditions be applied:

Code of Practice on Construction

Please apply

Noise Control

Before the development hereby permitted is first brought into use, a post installation BS4142:2014 assessment shall be carried out and submitted to the Local Planning Authority for approval, for the approved extraction system, to demonstrate impact on the nearest Noise Sensitive Receptors. Any works identified as required to ensure the rating noise is at least 5dB below the LA90 background noise shall be carried out prior to the first commercial use of the extraction system.