



Commercial Kitchens / Stainless Steel Wall Cladding / Ventilation / Gas Inter-Lock / Extraction Canopies

Suggested Maintenance Schedule for Proposed Extraction System at 12 Milton Rd

To ensure safe and efficient operation of the proposed extraction system, the following planned preventative maintenance is recommended:

Address of premises: 12 Milton Road, Gravesend DA12 2RE

Maintenance Frequency: Three visits per year.

Scope of Works:

- Deep cleaning of kitchen extract canopy.
- Deep cleaning of all associated extract ductwork.
- Deep cleaning and inspection of the Electrostatic Precipitator (ESP-4500E)
- Deep cleaning and inspection of the Exhaust Air Purification System with Motor (AMC5400VTA).
- Replacement of all filters during each maintenance visit.
- General inspection of system operation and condition.

System Access Panels:

It is confirmed that all system access panels will be grease tight.

This maintenance schedule is recommended to maintain system performance, minimise grease build-up, and assist in prolonging the operational life of the equipment.

Regards
Gabriele Cicconi
M&E Consulting Engineer
07751 545 245