



HARBOUR VILLAGE PHASE 1b

DETAILS TO ADDRESS PLANNING CONDITION 8 (REF: EDC/21/0081)

JUNE 2024 – REV A

BDG DESIGN ON BEHALF OF BELLWAY THAMES GATEWAY

CONTENTS

1 ELECTRIC VEHICLE CHARGING POINT LAYOUT.....2

1 ELECTRIC VEHICLE CHARGING POINT LAYOUT



- Legend
- EV Charging Point Wall Mounted
 - EV Charging Point Post Mounted
 - 2x EV Charging Point Post Mounted
- To include 3no. active EV charging spaces to the apartments.
- EV charging points to have a minimum output rating of 7kW- Mode 3, AC.
- All locations of chargers to be minimum of 3m away from lighting columns and any tree roots.