

Alison Webster
Gravesham Borough Council
Development Control
Civic Centre Windmill Street
Gravesend
Kent
DA12 1AU

Our ref: KT/2023/131054/01-L01
Your ref: 20230961
Date: 02 October 2023

Dear Alison,

Erection of a detached two bedroom bungalow.

Salem Yard, Salem Place, Northfleet, Gravesend, Kent, DA11 9QA

Thank you for consulting us on the above planning application. We have reviewed the information and have the following comments to make.

Environment Agency Position

We have **no objection** to the proposed development, subject to the **following condition(s)** being included on any permission granted.

Without this condition we would object to the proposal in line with paragraph 174 of the National Planning Policy Framework (NPPF).

Contamination

Condition:

If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until the developer has submitted, and obtained written approval from the Local Planning Authority for, a remediation strategy detailing how this unsuspected contamination shall be dealt with. The remediation strategy shall be implemented as approved, verified and reported to the satisfaction of the Local Planning Authority.

Reason:

There is always the potential for unexpected contamination to be identified during development groundworks. We should be consulted should any contamination be identified that could present an unacceptable risk to Controlled Waters.

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution from previously unidentified contamination sources at the development site in line with paragraph 174 of the National Planning Policy Framework.

Drainage

Condition:

No drainage systems infiltration of surface water drainage into the ground is permitted other than with the written consent of the Local Planning Authority. The development shall be carried out in accordance with the approved details.

Reason:

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution caused by mobilised contaminants in line with paragraph 174 of the National Planning Policy Framework.

Informative

Only clean uncontaminated water should drain to the surface water system. Roof drainage shall drain directly to the surface water system (entering after the pollution prevention measures). Appropriate pollution control methods (such as trapped gullies and interceptors) should be used for drainage from access roads and car parking areas to prevent hydrocarbons from entering the surface water system. There should be no discharge into land impacted by contamination or land previously identified as being contaminated. There should be no discharge to made ground. There must be no direct discharge to groundwater, a controlled water.

Advice to applicant

Note to applicant

Planning advice service

Should you wish us to review any technical documents or want further advice to meet the requirements of the conditions recommended, we may do this as part of our charged for planning advice service.

Further engagement will provide you with the opportunity to discuss and gain our views on potential options to overcome our objection with us, before formally submitting further information as part of your planning application/ certainty of our position as to what our response to your planning application will be. It should also result in a better quality and more environmentally sensitive development.

As part of our charged for service we will provide a dedicated project manager to act as a single point of contact to help resolve any problems. We currently charge £100 per hour, plus VAT. We will provide you with an estimated cost for any further discussions or review of documents. The standard terms of our charged for service are available [here](#).

If you would like more information on our planning advice service, including a cost estimate, please contact us at kslplanning@environment-agency.gov.uk.

Note to LPA

Condition Wording

If you wish to amend the wording of our requested conditions or if you wish to merge them with other Local Planning Authority conditions, please contact us to discuss the revised wording.

Decision notice

In accordance with the planning practice guidance ([determining a planning application, paragraph 019](#)), please notify us by email within two weeks of a decision being made or application withdrawn. Please provide us with a URL of the decision notice, or an electronic copy of the decision notice or outcome.

Should you have any queries regarding this response, please contact me.

Yours sincerely,

Connor Bowman
Sustainable Places Planning Specialist

Mobile +447771861844

E-mail kslplanning@environment-agency.gov.uk