

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 30/01/2025 3:05 PM from Ms Melanie McKenzie.

Application Summary

Address:	Land To The North And South Of Station Road Southfleet Gravesend Kent DA11 8HX
Proposal:	Proposed construction, operation and maintenance of a Battery Energy Storage System (BESS) with associated infrastructure (including batteries in storage containers, a substation and inverters) and works including highway access, landscaping and biodiversity enhancements.
Case Officer:	Mrs Lisa Fisher

[Click for further information](#)

Customer Details

Name:	Ms Melanie McKenzie
Email:	melanie.mckenzie@ukpowernetworks.co.uk
Address:	UK Power Networks Barton Road Bury St Edmunds

Comments Details

Commenter Type:	Consultee
Stance:	Customer made comments neither objecting to or supporting the Planning Application

Reasons for comment:

Comments:	Please note there are HV underground cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA. All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 (Avoiding Danger from Underground services). This document is available from local HSE office. We also note there are EHV overhead cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA. In the instance of overhead cables within the vicinity, GS6 (Advice on working near overhead powerlines) and a safety visit is required by UK Power Networks. Information and applications regarding GS6 can be found on our website https://www.ukpowernetworks.co.uk/safety-equipment/power-lines/working-near-power-lines/advice-on-working-near-overhead-power-lines-gs6#Apply Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG. You can also find support and application forms on our website Moving electricity supplies or equipment UK Power Networks Thank UK Power Networks
-----------	--

Kind regards