

20221064 Northfleet Harbourside - Land Surrounding Ebbsfleet United Football Club,  
Stonebridge Road, Northfleet

Thames Water 8 March 2024

Thames Water has reviewed this H4 consultation. Your client requires a build over agreement before commencing works, because we believe the proposed development is within 3 metres of a public sewer (of which, the internal diameter is less than or equal to 150mm).

Your client can find out more and apply on our [website](#) .

Please also advise your client, if applicable, that Thames Water do not permit driven piles within 15m of a public sewer. Our technical guidance can be found [here](#) .