

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 12/11/2025 11:54 AM from Planning Consents.

Application Summary

| | |
|---------------|---|
| Address: | Land Adjacent To Longfield Road Meopham Gravesend Kent DA13 0EW |
| Proposal: | Outline application for the erection of up to 120 residential dwellings, public open space and associated works. Approval is sought for the principal means of vehicular access from Longfield Road and all other matters are reserved. |
| Case Officer: | Mrs Alison Webster |

[Click for further information](#)

Customer Details

| | |
|----------|---|
| Name: | Planning Consents |
| Email: | planningconsents@ukpowernetworks.co.uk |
| Address: | UK Power Networks, Barton Road BURY ST. EDMUNDS |

Comments Details

| | |
|----------------------|---|
| Commenter Type: | Consultee |
| Stance: | Customer made comments neither objecting to or supporting the Planning Application |
| Reasons for comment: | |
| Comments: | Please note there are HV underground cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA. |

All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 (Avoiding Danger from Underground services). This document is available from local HSE office.

Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

You can also find support and application forms on our website Moving electricity supplies or equipment | UK Power Networks

Kind regards