

Tue 21/06/2022 10:37

From: Pete Wright

RE: 20220425 and 20220426 Prepworld, Unit K, Springhead Enterprise Park

To: Joyce, Kelly kelly.joyce@gravesham.gov.uk

Hi Kelly,

Thanks for email,

Yes I can confirm that the fascia sign illumination will be restricted to a maximum of 300 cd/m². I will pass this info now to the manufacturer so they can adjust their proposals.

Regards,

Pete