

Delegated Report

Prior Approval Extensions Application

Application no:	20221191
Location	Furzy Lea Bowesden Lane Shorne Gravesend
Proposal:	Single storey rear extension with a depth of 8.00 metres, maximum height of 3.50 metres and eaves height of 2.40 metres.
Applicant:	Mr Yadwinder Gill
Site Visit	N/A Desktop Assessment

Plans & Documents

Application Form Dated 03/11/2022;
Drawing Number 002 A (Site Location Plan and Block Plan);
Drawing Number 003 A (Floor Plans – Existing);
Drawing Number 005 A (Floor Plans – Proposed); and
Drawing Number 004 A (Elevations – Proposed).

Property Type

Furzy Lea, Bowesden Lane is a detached two storey dwellinghouse.

Proposal

The application seeks prior approval under Class A, Part 1 Schedule 2 and Article 3 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended) for the erection of a single storey rear extension with a depth of 4 metres, a maximum height of 3.46 metres and an eaves height of 2.38 metres.

Development Plan

Due to the nature of this application, the adopted plan and national planning policies are not relevant since it relates to whether the proposed single storey extension requires prior approval.

Planning Legislation

Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended)

Consultations, Publicity and Representations

No formal consultation was undertaken as there is no statutory requirement to consult third parties including parish councils or neighbours for lawful development certificate applications. However representations have been received from Shorne Parish Council and Dickens' Country Protection Society making the following comments;

Shorne Parish Council

This is a reapplication, further to the refusal by GBC of application Ref 20220995, with the extension relocated. As before, the Parish Council has no objection in principle to the property being extended to the rear, subject to there not being any significant valid objections from neighbours.

The house is relatively small for the size of its plot, it is located in the Green Belt and borders the AONB.

We note that the area of the proposed extension appears to be 8m by 4m (32sqm) but the area of the original/existing house is approximately 84sqm, so the proposed extension represents an increase in floor area of approximately 38%.

Dickens Protection Society

In view of the Green Belt Location and the size of the proposed extension the Society would suggest consent, if granted, is conditioned to remove permitted development rights for any further extensions.

Neighbouring Properties

In accordance with the amendments in relation to home extensions under paragraph A.4 (5) of Class A, Part 1, Schedule 2 of the Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended) the following adjoining neighbouring properties were notified of this application;

- The Silver Birches, Bowesden Lane
- Meadow Cottage, Bowesden Lane

No representations were received from the neighbouring properties consulted in this prior approval application. The consultation period expired 28th November 2022.

Relevant Planning History

Reference	Description	Decision	Decision Date
20220995	Single storey rear extension with a depth of 8.00 metres, maximum height of 3.50 metres and eaves height of 2.40 metres.	R3 - Prior Approval is Required and Refused	12.10.2022
20071061	Construction of new pitched roof to replace existing flat roof at rear and installation of new window in rear elevation at first floor level.	Permitted	18.01.2008
19940321	Erection of a conservatory at the rear.	Permitted	28.07.1994
19510115	Erection of a dwellinghouse and garage	Permitted	07.09.1951

Officer Assessment

Permitted Developments Rights Restrictions

Article 2 (3) Land (AONB, Conservation Area)	N
Article 4 Direction	N
Permitted Development Rights Removed/Restricted	N

Class A - The enlargement, improvement or other alteration of a dwellinghouse

A.1	Development is not permitted by Class A if –	Y/N
(a)	permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use)	N
(b)	as a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse)	N
(c)	the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse	N
(d)	the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse	N 2.36m
(e)	the enlarged part of the dwellinghouse would extend beyond a wall which – (i) forms the principal elevation of the original dwellinghouse; or (ii) fronts a highway and forms a side elevation of the original dwellinghouse	N N
(f)	subject to paragraph (g), the enlarged part of the dwellinghouse would have a single storey and – (i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height	Y 8m N 3.6m
(g)	for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and - (i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height;	N 8m N 3.6m

(h)	the enlarged part of the dwellinghouse would have more than a single storey and – (i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or (ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;	N/A N/A
(i)	the enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres	N Over 2m to boundary
(j)	the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would – (i) exceed 4 metres in height, (ii) have more than a single storey, or (iii) have a width greater than half the width of the original dwelling; or	N/A N/A N/A
(ja)	any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (e) to (j);	N
(k)	it would consist of or include – (i) the construction or provision of a verandah, balcony or raised platform, (ii) the installation, alteration or replacement of a microwave antenna, (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or (iv) an alteration to any part of the roof of the dwellinghouse	N N N N
(l)	the dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses)	N
A.2	In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if –	Y/N
(a)	it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;	N/A
(b)	the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or	N/A
(c)	the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.	N/A

(d)	any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in sub-paragraphs (b) and (c).	N/A
A.3	Development is permitted by Class A subject to the following conditions –	Y/N
(a)	the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;	N/A*
(b)	any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be – (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed; and	N/A N/A
(c)	where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable, be the same as the roof pitch of the original dwellinghouse.	N/A

*Assessment Note - although there was enough information to assess the Prior Approval Extension Application, some of the table above has been answered N/A as these parts of the GPDO cannot be definitively answered from the documents and plans provided. The proposed single storey rear extension would need to adhere to all of the above to be considered permitted development and further information would be required in the event of a submission to obtain a Lawful Development Certificate

Analysis

Under Class A.1 (g) of the Town and Country Planning (General Permitted Development) (GDPO) (England) Order 2015, as amended, a single family dwelling can extend beyond the rear wall by 8 metres in the case of a detached property, as long as it does not exceed 4 metres in height.

As set out in the GDPO, Class A.4 (2), the developer has provided sufficient information to support the application.

The information provided show the proposed development is within the parameters set out in the GPDO; 8 metres deep, a maximum height of 3.6 metres, with an eave height of 2.36 metres.

The adjoining properties were consulted in accordance with A.4 (5) and no representations were received. Therefore A.4 (7) has not been triggered and impact on neighbouring amenity does not require investigation.

It is considered that the details and documents provided with the application are sufficient and no further information is required under A.4 (8) to determine the proposed development.

Conclusion

The proposed development complies with **THE TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) (ENGLAND) ORDER 2015, AS AMENDED**, and it is considered **PRIOR APPROVAL IS NOT REQUIRED**, subject to the imposition of informatives relating to the extent of this prior approval, the

development to accord with the information provided, the time limit for completion, notification of completion and requirement to comply with Building Regulations and Party Wall Act.

Recommendation: PRIOR APPROVAL IS NOT REQUIRED

Case Officer:	Mrs Nina Goodbody	Team Leader:	Richard Hart
Signed:	^ [REDACTED]	Signed:	[REDACTED]
Dated:	29th November 2022	Dated:	29 th November 2022