



Valley Drive

Terrace T01

Block B

Block A

Maisonette M01

Proposed Tree to be relocated
to prevent interference with
proposed street lighting
column.

Proposed Tree to be relocated
to prevent interference with
proposed street lighting
column.

St Patrick's Gardens

St Patrick's Ga

ck's Gardens

Street Lighting Key:

Symbol	Description
	Lighting Column: Proposed galvanneal tubular steel raise & lower lighting column of 5.0 metre nominal height with a planted base with glass flake roof protection. Column to be manufactured to: EN 40, BS EN 1461 & BS 5649 standards
	Qty: 5
	Luminaire: Philips Luma Gen2 Micro factory fitted with rear shield
	Mounting Type: Post top mounted
	Manufacturer Ref: Luma Gen2 Micro BGP702 DN50 BL1 10 00 BLE D 5.25 CLD L90 740
	Lumen Output: 1.00klm
	Luminaire Wattage: 7 w
	Colour Temperature: 4000k Neutral White
	Luminaire Tilt: 0°
	Luminous Intensity: G3
	Control Gear: Electronic DALI enabled driver
	Control Type: Lucy Zodion ZCELL LED 20 lux (1:1 ratio)
	Dimming Profile: N/A
	Supply: To be confirmed by others
	Primary Isolator: To be confirmed by others
	Secondary Isolator: N/A

Denotes direction of travel for raise/lower lighting column

UNIT NUMBERING KEY:
Private lighting unit identification number

ELECTRICAL CONNECTION TYPE:
Electrical supply to be confirmed by others

LIGHTING ISOLUX CONTOUR KEY:
4.5 Isolux contour line
3.0 Isolux contour line
0.6 Isolux contour line

DRAWING TO BE PRINTED IN COLOUR TO ENABLE CORRECT IDENTIFICATION OF SYMBOLS, PROPOSED LIGHTING CABLING OR LAYOUTS SHOWN.

LIGHTING SCHEME DESIGNED IN ACCORDANCE WITH:
BS 5489-1:2020 & BS EN 13201-2:2015

S/P RATIO: N/A
MAINTENANCE FACTOR: 0.78

LIGHTING CLASSIFICATION: P5

MIN. MAINTAINED AVERAGE ILLUMINANCE (EAV): >3.00 lux <4.50 LUX
MIN. ILLUMINANCE (EMIN): >0.60 LUX
EMIN/EAV (UNIFORMITY): >0.20 (20%)

NO WORKS SHALL BE CONSTRUCTED UNTIL TECHNICAL APPROVAL HAS BEEN OBTAINED FROM THE LOCAL AUTHORITY BY THE DEVELOPER. SHOULD WORKS BE CONSTRUCTED WITHOUT APPROVAL, THEY WILL BE ENTIRELY AT THE DEVELOPERS RISK. UNLESS OTHERWISE STATED WITHIN THE QUOTATION PROVIDED BY MMA LIGHTING CONSULTANCY, MMA LIGHTING CONSULTANCY HAVE NOT SUBMITTED THIS DESIGN FOR TECHNICAL COMMENTS/APPROVAL.

NOTES:

ALL STREET LIGHTING IMPROVEMENTS WORK TO BE CARRIED OUT TO THE CURRENT CLIENTS SPECIFICATIONS AND AGREEMENTS.

CONTRACTOR TO CONFIRM POSITION OF STATUTORY UNDERTAKERS PLANT BEFORE COMMENCEMENT OF THE WORKS.

DURING WORKS ALL TRAFFIC MANAGEMENT TO BE IN ACCORDANCE WITH CHAPTER 8 OF THE TRAFFIC SIGNS MANUAL.

PROPOSED LIGHTING COLUMNS ARE TO BE LOCATED TO THE REAR OF THE FOOTPATH WHEREVER POSSIBLE OR A MINIMUM OF 1000mm SETBACK FROM FRONT KERB EDGING.

ANY EXISTING OR PROPOSED TREES ARE TO BE CUTBACK, REMOVED OR RELOCATED TO AVOID INTERFERENCE WITH THE STREET LIGHTING LUMINAIRE OR PREVENT ANY FUTURE MAINTENANCE.

IF THE AUTHORITY OR CONTRACTOR EXPERIENCE ANY PART DISCREPANCY BETWEEN THIS DRAWING OR ANY OF THE DOCUMENTS RELATING TO THIS SITE THE AUTHORITY OR CONTRACTOR MUST CONTACT THE LIGHTING DESIGNER FOR CLARIFICATION.

UNIT NUMBERS SHOWN ARE FOR DESIGN IDENTIFICATION PURPOSES ONLY. FINAL COLUMN NUMBERING SHALL BE AGREED WITH THE OVERSEEING ORGANISATION.

REV	AMENDMENT	DATE	INITIAL
R0	INITIAL DESIGN - BASE DRAWING USED 'SCC-BPTW-04-00-M2-A-0210-C03-A3'	16/04/2024	BR

MMA

LIGHTING CONSULTANCY

Exterior Lighting Design Specialists

99 Old Bath Road, Summer Field House, Reading, RG10 9QN
Phone: 0118 321 5636 Email: info@mma-consultancy.co.uk
www.mma-consultancy.co.uk

Project title LAND AT ST. COLUMBA'S, GRAVESEND DA12	
Drawing title PRIVATE STREET LIGHTING DESIGN SHEET 1 OF 1	
Prepared by BR	Checked by HC
Scale 1:250 @ A1	Date 16/04/2024
Drawing Number MMA18541/001	Revision Details R0

0 1:250 12.5 metres

CURRENT STATUTORY SERVICE RECORD PLANS SHOULD BE OBTAINED BY THE CONTRACTOR/OVERSEEING ORGANISATION BEFORE COMMENCEMENT OF ANY STREET LIGHTING INSTALLATION OR REMOVAL WORKS.
ALL SERVICES ARE TO BE LOCATED AND IDENTIFIED PRIOR TO INSTALLING OR REMOVING ANY LIGHTING COLUMNS. WORKS SHOULD BE CARRIED OUT IN ACCORDANCE WITH HSE G56, ENA 434, HSE H6587, CS81 AND ALL RELEVANT HSE REGULATIONS.

DETAILS OF EXISTING STATUTORY UNDERTAKERS PLANT ARE TO BE OBTAINED BY THE CLIENT AND THE CONTRACTOR MAY EXAMINE THESE RECORDS AT THE ENGINEERS OFFICE. ALL WORKS IN THE VICINITY OF ANY OVERHEAD CABLES SHALL CONFORM TO THE REQUIREMENTS OF HSE GUIDANCE NOTE G56 "AVOIDANCE OF DANGER FROM OVERHEAD LINES" AND ALL WORKS IN THE VICINITY OF UNDERGROUND MAINS OR CABLES SHALL CONFORM TO THE REQUIREMENTS OF HSE GUIDANCE NOTE H6587 "AVOIDING DANGER FROM UNDERGROUND SERVICES" AND ANY ADDITIONAL REQUIREMENTS SPECIFIED BY THE RELEVANT UNDERTAKER.

THE CONTRACTOR WILL BE RESPONSIBLE FOR LIAISON WITH THE UNDERTAKERS AND FOR PROGRAMMING THE AGREED PROTECTION AND/OR DIVERSION WORKS TO ANY STATUTORY UNDERTAKERS APPARATUS INTO THE OVERALL WORKS PROGRAMME (THIS IS TO INCLUDE ADJUSTMENT OF STAFF COVERS).

ANY DAMAGE TO PLANT OR APPARATUS SHALL BE REPAIRED AT THE CONTRACTORS EXPENSE.

NO WORKS SHALL BE CONSTRUCTED UNTIL TECHNICAL APPROVAL HAS BEEN OBTAINED FROM THE OVERSEEING ORGANISATION BY THE DEVELOPER. NO WORKS SHALL BE CONSTRUCTED WITHOUT APPROVAL, IF CARRIED OUT THEN THEY WILL BE ENTIRELY AT THE DEVELOPERS RISK. UNLESS OTHERWISE STATED WITHIN THE QUOTATION PROVIDED BY MMA LIGHTING CONSULTANCY, THIS DESIGN HAS NOT BEEN SUBMITTED FOR TECHNICAL APPROVAL.