

From: [KSLPlanning](#)
To: [Planning Admin](#)
Subject: RE: Planning Application Consultation for application 20240283
Date: 17 April 2024 11:46:19

Caution: This email was sent from outside of the organisation. Do not click on links or open attachments unless you recognise the sender.

Apologies- please use this response instead:

Thank you for consulting us. Due to the scale, nature and setting of this proposal and the supporting information submitted, we have assessed this proposal as low risk. We therefore do not have any specific comments to add.

The Environment Agency's Approach to Groundwater Protection

We recommend the applicant/enquirer refers to our groundwater position statements in 'The Environment Agency's approach to groundwater protection', available from gov.uk. This publication sets out our position for a wide range of activities and developments, including:

Waste management

Discharge of liquid effluents

Land contamination

Ground source heat pumps

Cemetery developments

Drainage

Land contamination: risk management and good practice

We recommend that developers should:

Follow the risk management framework provided in Land Contamination: Risk Management, when dealing with land affected by contamination

Refer to our Guiding principles for land contamination for the type of information that we require in order to assess risks to controlled waters from the site - the local authority can advise on risk to other receptors, such as human health

Consider using the National Quality Mark Scheme for Land Contamination Management which involves the use of competent persons to ensure that land contamination risks are appropriately managed

Refer to the contaminated land pages on gov.uk for more information

Drainage and infiltration

Only clean uncontaminated water should drain to the surface water system. Roof drainage shall drain directly to the surface water system (entering after the pollution prevention measures). Appropriate pollution control methods (such as trapped gullies and interceptors) should be used for drainage from access roads and car parking areas to prevent hydrocarbons from entering the surface water system. There should be no discharge

into land impacted by contamination or land previously identified as being contaminated. There should be no discharge to made ground. There must be no direct discharge to groundwater, a controlled water.

Discharge of treated sewage effluent

If you are proposing a non-mains drainage solution the following form should be completed:

<https://www.gov.uk/government/publications/foul-drainage-assessment-form-fda1>

The discharge of domestic sewage associated with this development may be subject to General Binding Rules (GBRs) under the Environmental Permitting (England & Wales) Regulations 2016, which provide a statutory baseline of good practice. You can find more information online at <https://www.gov.uk/permits-you-need-for-septic-tanks/permits> or contact us on 03708 506506. If your proposal cannot meet the GBRs then a permit will likely be required.

Please note that our advice is applicable for the information made available to us at this point. If, at any stage, this information changes, we will need to be informed and re-consulted.

Kind regards

Laura Edwards

Kent and South London Sustainable Places Team

kslplanning@environment-agency.gov.uk

-----Original Message-----

From: KSLPlanning

Sent: Wednesday, April 17, 2024 11:44 AM

To: planning.admin@gravesham.gov.uk

Subject: RE: Planning Application Consultation for application 20240283

Thank you for consulting us on the above planning application.

We have assessed this application as having a low environmental risk. We therefore have no comments to make.

Non planning consents

Although we have no comments on this planning application, the applicant may be required to apply for other consents directly from us. The term 'consent' covers consents, permissions or licences for different activities (such as water abstraction or discharging to a stream), and we have a regulatory role in issuing and monitoring them.

The applicant should contact 03708 506 506 or consult our website (<https://www.gov.uk/guidance/check-if-you-need-an-environmental-permit>) to establish whether a consent will be required.

Drainage may be restricted in a Source Protection Zone or over an aquifer where groundwater is at shallow depths. Foul drainage should be discharged to mains sewers where possible. Developers should check <https://www.gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h> for Binding Rules information for small scale non mains discharges.

If you feel we should assess this planning application in more detail due to local issues please email KSLPLANNING@environment-agency.gov.uk.

-----Original Message-----

From: planning.admin@gravesham.gov.uk <planning.admin@gravesham.gov.uk>

Sent: Wednesday, April 3, 2024 8:55 AM

To: KSLPlanning <KSLPLANNING@environment-agency.gov.uk>

Subject: Planning Application Consultation for application 20240283

Warning: The sender of this message could not be validated. Please use caution when opening any message content such as attachments or links

Please refer to the attached Consultation Document for reference 20240283 at Plot 19.

Regards,

Planning Team, Gravesham Borough Council.

This message has been sent using TLS 1.2

Information in this message may be confidential and may be legally privileged. If you have received this message by mistake, please notify the sender immediately, delete it and do not copy it to anyone else. We have checked this email and its attachments for viruses. But you should still check any attachment before opening it. We may have to make this message and any reply to it public if asked to under the Freedom of Information Act, Data Protection Act or for litigation. Email messages and attachments sent to or from any Environment Agency address may also be accessed by someone other than the sender or recipient, for business purposes.