

Delegated Report

Lawful Development Certificate (Proposed)

Application no:	20230687
Location	19 Clipper Crescent Gravesend Kent DA12 4NW
Proposal:	Application for a Proposed Lawful Development Certificate in respect of conversion of the loft space into habitable room incorporation of hip to gable roof extension with rear dormer and front slope velux lights.
Applicant:	Mr Phil Costley
Site Visit	N/A Desktop Assessment

Plans & Documents

Application Form Dated 26/06/2023;
 Site Location Plan Received 29/06/2023;
 Block Plan Received 29/06/2023;
 Drawing Number 101 (Plans and Elevations – Existing); and
 Drawing Number 201 (Plans and Elevations with Section Plan – Proposed).

Property Type

19 Clipper Crescent is a two-storey semi-detached dwellinghouse.

Material Consideration

Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended)

Relevant Planning History

Reference	Description	Decision	Decision Date
20190463	Application for a Lawful Development Certificate in respect of the proposed erection of an outbuilding in the rear garden.	Certificate Granted	03.07.2019
20190456	Single storey rear extension with a depth of 4.5 metres, 3.1maximum height of 3.0 metres and eaves	Prior Approval Not Required	19.06.2019
20190356	Single storey rear extension with a depth of 4.5 metres, maximum height of 3.0 metres and eaves height of 3.0 metres.	Prior Approval Not Required	23.05.2019

Officer Assessment

Permitted Developments Rights Restrictions

Article 2 (3) Land (AONB, Conservation Area)	N
Article 4 Direction	N
Permitted Development Rights Removed/Restricted	N

Class B - The enlargement of a dwellinghouse consisting of an addition or alteration to its roof.

1, Original Roof Volume (m ³)	N/A
2. Existing Roof Extensions (m ³)	N/A
Remaining Roof Volume (m ³)	N/A No previous roof works have been undertaken. 50m ³ roof volume remains.

B.1	Development is not permitted by Class B if –	Y/N
(a)	Permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use);	N
(b)	Any part of the dwellinghouse would, as a result of the works, exceed the height of the highest part of the existing roof;	N
(c)	Any part of the dwellinghouse would, as a result of the works, extend, beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway;	N
(d)	The cubic content of the resulting roof space would exceed the cubic content of the original roof space by more than – (i) 40 cubic metres in the case of a terrace house, or (ii) 50 cubic metres in any other case;	N 33.41 m ³
(e)	It would consist of or include – the construction or provision of a verandah, balcony or raised platform or the installation, alteration or replacement of a chimney, flue or soil and vent pipe; or	N N
(f)	The dwellinghouse is on article 2 (3) land	N
B.2	Development is permitted by Class B subject to the following conditions –	Y/N
(a)	The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;	Y

(b)	The enlargement must be constructed so that – (i) other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side – extension (aa) the eaves of the original roof are maintained or reinstated; and (bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the eaves; and (ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwelling house; and	Y Y Y
(c)	Any window inserted on a wall or roof slope forming a side elevation of the dwellinghouse must be – (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.	Y Y

Class C - Any other alteration to the roof of a dwellinghouse.

C.1	Development is not permitted by Class C if -	Y/N
(a)	permission to use the dwelling as a dwellinghouse has been granted only by virtue of Class M, N, P, PA or Q of Part 3 of this Schedule (changes of use);	N
(b)	the alteration would protrude more than 0.15 metres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof;	N
(c)	it would result in the highest part of the alteration being higher than the highest part of the original roof;	N
(d)	it would consist of or include – (i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or (ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment.	N N
C.2	Development is permitted by Class C subject to the condition that any window located on a roof slope forming a side elevation of the dwellinghouse must be- (a) obscure-glazed; and (b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.	Y Y

Conclusion

The proposed alterations comply with Schedule 2, Part 1, Classes B and C of The Town and Country Planning (General Permitted Development) (England) Order 2015, as amended. Therefore, planning permission is not required and a Lawful Development Certificate can be granted.

Recommendation: Grant Lawful Development Certificate

Case Officer:	Mrs Nina Goodbody	Team Leader:	Miss Faye Hobbs
Signed:	<i>N Goodbody</i>	Signed:	
Dated:	15th August 2023	Dated:	15 August 2023