



To: **Planning Reps**
From **Highways Development Management Officer**

Date 25th August 2021

Your Ref 20211037

Location 55 Rochester Road Gravesend Kent

I have no objections to the proposal, but would prefer the car parking at the front of the property removed due to its proximity to the public highway which could result in a vehicle having to wait on the road whilst another vehicle completes its manoeuvring to the detriment of highway safety and the free flow of traffic.

All rear parking spaces should be wired to accommodate electric vehicle charging points of a minimum 7kW continuous supply, (more under surge conditions)

Les Seaborn
Highways Development Management Officer

