



Gravesham Borough Council
Civic Centre
Windmill Street
Kent
DA12 1AU

Your ref
20250036

Our ref
DSA000041233

Date
20/02/2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Application for the approval of condition 6 (Surface Water Drainage) attached to planning reference number 20230136 relating to a scheme for sustainable surface water drainage.
Site: Land At, Worcester Close, Istead Rise, Gravesend Kent.

Thank you for your correspondence dated the 11th of February 2025, please see our comments below regarding the above application.

From reviewing the submitted documents, Southern Water is happy to discharge condition 6 (Surface Water Drainage) due to the submitted drainage diagram showing the proposed Soakaway being the required 5m away from the existing Water pipe.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development