

Considine Limited		Page 1
25 Hollingworth Court	3474	
Kent	2 VALE ROAD	
ME14 5PP	NETWORK - P01	
Date 02/11/2021 11:29	Designed by MJF	
File 3474-Network-P01.MDX	Checked by JEM	
Innovyze	Network 2020.1.3	
<u>100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm</u> <u>Simulation Criteria</u> Areal Reduction Factor 1.000 Manhole Headloss Coeff (Global) 0.500 MADD Factor * 10m³/ha Storage 2.000 Hot Start (mins) 0 Foul Sewage per hectare (l/s) 0.000 Inlet Coefficient 0.800 Hot Start Level (mm) 0 Additional Flow - % of Total Flow 0.000 Flow per Person per Day (l/per/day) 0.000 Number of Input Hydrographs 0 Number of Offline Controls 0 Number of Time/Area Diagrams 0 Number of Online Controls 1 Number of Storage Structures 1 Number of Real Time Controls 0 <u>Synthetic Rainfall Details</u> Rainfall Model FEH Data Type Point FEH Rainfall Version 2013 Cv (Summer) 0.750 Site Location GB 562797 173610 TQ 62797 73610 Cv (Winter) 0.840 Margin for Flood Risk Warning (mm) 300.0 DVD Status ON Analysis Timestep 2.5 Second Increment (Extended) Inertia Status ON DTS Status ON Profile(s) Summer and Winter Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440 Return Period(s) (years) 100 Climate Change (%) 40 WARNING: Half Drain Time has not been calculated as the structure is too full.		
©1982-2020 Innovyze		

Considine Limited		Page 2
25 Hollingworth Court	3474	
Kent	2 VALE ROAD	
ME14 5PP	NETWORK - P01	
Date 02/11/2021 11:29	Designed by MJF	
File 3474-Network-P01.MDX	Checked by JEM	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

								Water	Surcharged	Flooded	Half Drain			Pipe		
US/MH		Return	Climate	First (X)	First (Y)	First (Z)	Overflow	Level	Depth	Volume	Flow /	Overflow	Time	Flow		
PN	Name	Storm	Period	Change	Surcharge	Flood	Overflow	Act.	(m)	(m)	(m³)	Cap.	(l/s)	(mins)	(l/s)	Status

PN	US/MH	Level	Name	Exceeded
----	-------	-------	------	----------

Considine Limited														Page 3	
25 Hollingworth Court						3474									
Kent						2 VALE ROAD									
ME14 5PP						NETWORK - P01									
Date 02/11/2021 11:29						Designed by MJF									
File 3474-Network-P01.MDX						Checked by JEM									
Innovyze						Network 2020.1.3									
100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm															
		US/MH		Return	Climate	First (X)	First (Y)	First (Z)	Overflow	Water	Surcharged	Flooded			Half Drain
PN	Name	Storm		Period	Change	Surcharge	Flood	Overflow	Act.	Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Time (mins)
S1.000	SRE1.1	15 Winter		100	+40%	100/15 Summer				22.652	0.602	0.000	0.56		
S1.001	SS1	15 Winter		100	+40%	100/15 Summer				22.582	0.762	0.000	1.43		
S2.000	SRE1.2	15 Winter		100	+40%	100/15 Summer				22.429	0.379	0.000	0.21		
S1.002	SJUNCT	15 Summer		100	+40%					21.725	0.000	0.000	1.41		
S1.003	SS2	15 Winter		100	+40%	100/15 Summer				22.246	0.467	0.000	0.32		
S3.000	SRE2.1	360 Winter		100	+40%	100/15 Summer				22.244	0.194	0.000	0.01		
S1.004	SJUNCT	15 Summer		100	+40%					21.583	0.000	0.000	0.36		
S1.005	SS3	360 Winter		100	+40%	100/15 Summer				22.243	1.079	0.000	0.16		
S4.000	SRE3.1	360 Winter		100	+40%	100/15 Summer				22.243	0.472	0.000	0.04		
S1.006	SJUNCT	15 Summer		100	+40%					21.154	0.000	0.000	0.66		
S5.000	SRE4.1	360 Winter		100	+40%	100/15 Winter				22.242	0.287	0.000	0.04		
S1.007	SS4	360 Winter		100	+40%	100/15 Summer				22.242	1.181	0.000	0.12		
S6.000	SRE5.1	15 Winter		100	+40%	100/15 Summer				22.301	0.147	0.000	0.93		
S6.001	SS5	360 Winter		100	+40%	100/15 Summer				22.243	0.195	0.000	0.09		
S7.000	SRE6.1	360 Winter		100	+40%	100/15 Winter				22.242	0.386	0.000	0.01		
S6.002	SS6	360 Winter		100	+40%	100/15 Summer				22.242	1.274	0.000	0.14		
S1.008	SJUNCT	15 Summer		100	+40%					20.928	0.000	0.000	2.00		
S8.000	SRE7.1	15 Winter		100	+40%	100/15 Summer				22.543	0.743	0.000	1.64		
S9.000	SRE7.2	15 Winter		100	+40%	100/15 Summer				22.463	0.708	0.000	0.53		
S8.001	SS7	15 Winter		100	+40%	100/15 Summer				22.432	0.838	0.000	1.58		
S10.000	SRE8.1	360 Winter		100	+40%	100/15 Summer				22.243	0.452	0.000	0.05		
S8.002	SS8	360 Winter		100	+40%	100/15 Summer				22.242	0.778	0.000	0.16		
S11.000	SRE9.1	15 Winter		100	+40%	100/15 Summer				23.076	0.496	0.000	1.20		
S12.000	SRE9.2	360 Winter		100	+40%	100/15 Summer				22.241	0.248	0.000	0.00		
S11.001	SS9	360 Winter		100	+40%	100/15 Summer				22.241	0.346	0.000	0.33		
©1982-2020 Innovyze															

Considine Limited				Page 4
25 Hollingworth Court		3474		
Kent		2 VALE ROAD		
ME14 5PP		NETWORK - P01		
Date 02/11/2021 11:29		Designed by MJF		
File 3474-Network-P01.MDX		Checked by JEM		
Innovyze		Network 2020.1.3		
<u>100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm</u>				
PN	US/MH Name	Pipe Flow (l/s)	Status	Level Exceeded
S1.000	SRE1.1	4.9	FLOOD RISK	
S1.001	SS1	8.8	FLOOD RISK	
S2.000	SRE1.2	2.5	FLOOD RISK	
S1.002	SJUNCT	11.1	SURCHARGED*	
S1.003	SS2	18.9	SURCHARGED	
S3.000	SRE2.1	0.2	SURCHARGED	
S1.004	SJUNCT	25.1	SURCHARGED*	
S1.005	SS3	4.9	SURCHARGED	
S4.000	SRE3.1	0.7	SURCHARGED	
S1.006	SJUNCT	28.4	SURCHARGED*	
S5.000	SRE4.1	0.9	SURCHARGED	
S1.007	SS4	6.3	SURCHARGED	
S6.000	SRE5.1	6.8	SURCHARGED	
S6.001	SS5	3.7	SURCHARGED	
S7.000	SRE6.1	0.2	FLOOD RISK	
S6.002	SS6	4.2	SURCHARGED	
S1.008	SJUNCT	59.8	SURCHARGED*	
S8.000	SRE7.1	10.6	FLOOD RISK	
S9.000	SRE7.2	4.3	FLOOD RISK	
S8.001	SS7	12.6	FLOOD RISK	
S10.000	SRE8.1	0.6	FLOOD RISK	
S8.002	SS8	5.0	SURCHARGED	
S11.000	SRE9.1	14.4	FLOOD RISK	
S12.000	SRE9.2	0.0	SURCHARGED	
©1982-2020 Innovyze				

Considine Limited		Page 5											
25 Hollingworth Court	3474												
Kent	2 VALE ROAD												
ME14 5PP	NETWORK - P01												
Date 02/11/2021 11:29	Designed by MJF												
File 3474-Network-P01.MDX	Checked by JEM												
Innovyze	Network 2020.1.3												
<u>100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm</u>													
<table><thead><tr><th>PN</th><th>US/MH Name</th><th>Pipe Flow (l/s)</th><th>Status</th><th>Level Exceeded</th></tr></thead><tbody><tr><td>S11.001</td><td>SS9</td><td>2.4</td><td>SURCHARGED</td><td></td></tr></tbody></table>				PN	US/MH Name	Pipe Flow (l/s)	Status	Level Exceeded	S11.001	SS9	2.4	SURCHARGED	
PN	US/MH Name	Pipe Flow (l/s)	Status	Level Exceeded									
S11.001	SS9	2.4	SURCHARGED										
©1982-2020 Innovyze													

