



Katherine Parkin
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Flood and Water Management

Invicta House
Maidstone
Kent
ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: GBC/2021/087051
Date: 7 June 2022

Application No: 20211215

Location: Hevercourt Residential Home, Goodwood Crescent, Gravesend, Kent DA12 5EY

Proposal: Single storey 'wing' extensions to north, east, south and west elevations to provide an additional 21 ground floor ensuite bed spaces and additional care home facilities, together with internal and external alterations including a new entrance and entrance canopy to the south elevation, external courtyards, a new compound area, 7 additional car parking spaces and landscaping.

Thank you for your consultation on the above referenced planning application.

Kent County Council as Lead Local Flood Authority have reviewed the Drainage Strategy Report prepared by vkhp Consulting dated 22 February 2022 and agree in principle to the proposed development.

The proposals seek to utilise downpipes from roofs and underground piped networks leading to an attenuation tank with infiltration to ground.

Should your authority be minded to grant permission for the proposed development, we recommend the following conditions are attached:

Condition:

Development shall not begin in any phase until a detailed sustainable surface water drainage scheme for the site has been submitted to (and approved in writing by) the local planning authority. The detailed drainage scheme shall be based upon the Drainage Strategy Report prepared by vkhp Consulting dated 22 February 2022 and shall demonstrate that the surface water generated by this development (for all rainfall durations and intensities up to and including the climate change adjusted critical 100 year storm) can be accommodated and disposed of without increase to flood risk on or off-site.

The drainage scheme shall also demonstrate (with reference to published guidance):

- that silt and pollutants resulting from the site use can be adequately managed to ensure there is no pollution risk to receiving waters.
- appropriate operational, maintenance and access requirements for each drainage feature or SuDS component are adequately considered, including any

proposed arrangements for future adoption by any public body or statutory undertaker.

The drainage scheme shall be implemented in accordance with the approved details.

Reason:

To ensure the development is served by satisfactory arrangements for the disposal of surface water and to ensure that the development does not exacerbate the risk of on/off site flooding. These details and accompanying calculations are required prior to the commencement of the development as they form an intrinsic part of the proposal, the approval of which cannot be disaggregated from the carrying out of the rest of the development.

Condition:

No building on any phase (or within an agreed implementation schedule) of the development hereby permitted shall be occupied until a Verification Report, pertaining to the surface water drainage system and prepared by a suitably competent person, has been submitted to and approved by the Local Planning Authority. The Report shall demonstrate that the drainage system constructed is consistent with that which was approved. The Report shall contain information and evidence (including photographs) of details and locations of inlets, outlets and control structures; landscape plans; full as built drawings; information pertinent to the installation of those items identified on the critical drainage assets drawing; and, the submission of an operation and maintenance manual for the sustainable drainage scheme as constructed.

Reason:

To ensure that flood risks from development to the future users of the land and neighbouring land are minimised, together with those risks to controlled waters, property and ecological systems, and to ensure that the development as constructed is compliant with and subsequently maintained pursuant to the requirements of paragraph 165 of the National Planning Policy Framework.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

John Burns

Senior Flood Risk Project Officer
Flood and Water Management