

FIRE SAFETY STATEMENT

131 Central Avenue,
Gravesend, DA12 5BH

INTRODUCTION

This statement has been prepared on behalf of the applicants by the agent Freedom Homes Architects. Registered with ARB and a member of the RIBA.

This statement sets out how the proposed scheme will comply with London Plan Policy D12A. In line with the Fire Safety Policy 12D(A) Pre-consultation Draft March 2021 Table A1.1 Please note that this document has been supplied for information only and does not in itself constitute a proposal to comply with the building regulations. I confirm that the proposed design will be fully compliant with the current Building Regulations which include:

1. An FD 30 fire door enclosing the proposed extension area, separating the kitchen area from the property. There will be a 30 min fire-resistant escape route for the loft.
2. Have a mains powered optical smoke detector at each floor level with battery back up to BS 5839-Part 6, grade D, category LD3 standard. Wired on a separate circuit distribution board with heat resistant cable made identifiable.
3. The front of the property is unobstructed to allow access for fire fighting vehicles/appliances.

I trust this is to your requirements.