


Environmental Protection COMMENTS

Case Number	20240910
Case Officer	Mrs Lucy Hankin
Address	Land At Stoney Wood, Wrotham Road, South Street, Meopham, Kent, DA13 0QG

Proposal	Application for the change of use of land from agricultural to C3 dwellinghouse, proposal to convert the existing agricultural barn into a single self build dwelling with associated hard and soft landscaping.
Consultation Expiry Date	10 December 2024
Date of Response	13 December 2024 (JO)

Apologies for the delay in responding. This is due to workload and leave. There is no objection to this application but as the land has been in agricultural/storage use and is being converted to residential, a contaminated land assessment will be needed.

To address this and other matters, the following are recommended:



Contaminated Land

No development approved by this permission shall be commenced prior to a contaminated land assessment (in accordance with the Environment Agency's Land Contamination Risk Management (LCRM) guidance) and if necessary an associated remedial strategy, together with a timetable of works, being submitted to the Local Planning Authority for approval.

- a) The contaminated land assessment shall include a desk study to be submitted to the Local Planning Authority for approval. The desk study shall detail the history of the site uses and propose a site investigation strategy based on the relevant information discovered by the desk study. The strategy shall be approved by the Local Planning Authority prior to investigations commencing on site.
- b) The site investigation, including relevant soil, soil gas, surface and groundwater sampling, shall be carried out by a suitably qualified and accredited consultant/contractor in accordance with a Quality Assured sampling and analysis methodology.
- c) A site investigation report detailing all investigative works and sampling on site, together with the results of analysis, risk assessment to any receptors and a proposed remediation strategy shall be submitted to the Local Planning Authority. The Local Planning Authority shall approve such remedial works as required prior to any remediation commencing on site. The works shall be of such a nature so as to render harmless the identified contamination given the proposed end-use of the site and surrounding environment including any controlled waters.
- d) Approved remediation works shall be carried out in full on site under a quality assurance scheme to demonstrate compliance with the proposed methodology and best practice guidance). If during any works contamination is encountered which has not previously been identified then the additional contamination shall be fully assessed and an appropriate remediation scheme agreed with the Local Planning Authority.
- e) Upon completion of the works, this condition shall not be discharged until a closure report has been submitted to and approved by the Local Planning Authority. The closure report shall include details of the proposed remediation works and the quality assurance certificates to show that the works have been carried out in full in accordance with the approved methodology. Details of any post remediation sampling and analysis to show the site has reached the required clean-up criteria shall be included in the closure report together with the necessary documentation detailing what waste materials have been removed from the site.
- f) Where applicable, a monitoring and maintenance scheme to include monitoring the long-term effectiveness of the proposed remediation over an agreed period of time, and the provision of reports on the same, must be prepared and approved in writing by the local planning authority.

Following completion of the measures identified in that scheme, and when the remediation objectives have been achieved, reports that demonstrate the effectiveness of the monitoring and maintenance carried out must be produced and submitted to the local planning authority.

Lighting

Artificial lighting can cause a statutory nuisance under the Environmental Protection Act 1990. It is important that the applicants are not permitted to install external lighting that illuminate anything other than the ground within the curtilage of the new properties in order to assist in preventing a nuisance from occurring (which would be most likely if the bedrooms on neighbouring properties

are illuminated).

Drainage/sewerage informative

The foul sewage shall be removed by means of the mains drainage system and not by the use of non-mains sewerage systems, unless connection to the drainage system is not reasonably practicable. If foul sewage is to be removed using non-mains sewerage systems, a sewage treatment plant or septic tank system will be considered in preference to a cesspool. Such a system may require the prior consent of the Environment Agency under the terms of the Water Resources Act 1991. Applicants are therefore advised to discuss their requirements with the Environment Agency at the earliest opportunity. It should be ensured that the septic tank or cesspool is of adequate capacity to serve the proposed development and suitable access and hardstanding area shall be maintained to it on site.