

Kathrine Parkin
Gravesham Borough Council
Development Control
Civic Centre Windmill Street
Gravesend
Kent
DA12 1AU

Our ref: KT/2023/131144/01-L01
Your ref: 20231050
Date: 16 November 2023

Dear Katherine,

Erection of a portal frame shed for servicing and maintaining coaches, including space for an office on a mezzanine floor and storage on the ground floor.

Grange Travel Limited, Canal Road, Gravesend, Kent, DA12 2RS

Thank you for consulting us on the above planning application on 27 October 2023.

We have reviewed the below information and have the following comments to make:

- Flood Risk Assessment (FRA) (Grange Travel, Dated: February 2022)

Environment Agency position

We have **no objection** to the proposed development, subject to the **following conditions** being included on any permission granted.

Without these conditions we would object in line with Paragraph 174 of the National Planning Policy Framework (NPPF).

Condition: Contamination Investigation

No development approved by this planning permission shall commence until a strategy to deal with the potential risks associated with any contamination of the site has been submitted to, and approved in writing by, the Local Planning Authority. This strategy will include the following components:

1. A preliminary risk assessment which has identified:
 - all previous uses;
 - potential contaminants associated with those uses;
 - a conceptual model of the site indicating sources, pathways and receptors; and
 - potentially unacceptable risks arising from contamination at the site.
2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.

3. The results of the site investigation and the detailed risk assessment referred to in (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the remediation strategy in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the written consent of the local planning authority. The scheme shall be implemented as approved.

Reason:

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution in line with paragraph 174 of the National Planning Policy Framework.

Condition: Contamination Verification

Prior to any part of the permitted development being occupied a verification report demonstrating the completion of works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to, and approved in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met.

Reason:

To ensure that the site does not pose any further risk to human health or the water environment by demonstrating that the requirements of the approved verification plan have been met and that remediation of the site is complete. This is in line with paragraph 174 of the National Planning Policy Framework.

Condition: Unsuspected Contamination

If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until a remediation strategy detailing how this contamination will be dealt with has been submitted to and approved in writing by the Local Planning Authority. The remediation strategy shall be implemented as approved.

Reason:

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution from previously unidentified contamination sources at the development site in line with paragraph 174 of the National Planning Policy Framework.

Condition: Surface Water Drainage

No drainage systems infiltration of surface water drainage into the ground is permitted other than with the written consent of the Local Planning Authority. The development shall be carried out in accordance with the approved details.

Reason:

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution caused by mobilised contaminants in line with paragraph 174 of the National Planning Policy Framework.

Condition: Piling

Piling or any other intrusive works shall not be permitted other than with the express written consent of the Local Planning Authority, which may be given for those parts of the site where it has been demonstrated by a piling risk assessment that there is no resultant unacceptable risk to groundwater. The development shall be carried out in accordance with the approved details.

Reason:

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution caused by mobilised contaminants in line with paragraph 174 of the National Planning Policy Framework.

Condition: Above ground storage of oils, fuels or chemicals and pollution management plan

No occupation of any part of the permitted development shall take place until a Pollution Management Plan is submitted to and approved, in writing, by the local planning authority.

Reason:

To prevent pollution of controlled waters and comply with the NPPF. The plan must outline what monitoring and surveillance procedures are in place to mitigate the risks to the environment from fuel spillages at the site, and what provisions are available on site to deal with a spillage (e.g. spill kits etc.).

Informative

Surface Water Drainage

Only clean uncontaminated water should drain to the surface water system. Roof drainage shall drain directly to the surface water system (entering after the pollution prevention measures). Appropriate pollution control methods (such as trapped gullies and interceptors) should be used for drainage from access roads and car parking areas to prevent hydrocarbons from entering the surface water system. There should be no discharge into land impacted by contamination or land previously identified as being contaminated. There should be no discharge to made ground. There must be no direct discharge to groundwater, a controlled water.

Foul Drainage

It is understood that there is to be no domestic effluent produced on site and as such no foul drainage plans have been proposed. This is acceptable in principle, however, should these plans change in the future we would wish to be consulted further.

Piling

Piling can result in risks to groundwater quality by mobilising contamination when boring through different bedrock layers and creating preferential pathways. Thus, it should be demonstrated that any proposed piling will not result in contamination of groundwater. If Piling is proposed, a Piling Risk Assessment must be submitted, written in accordance with EA guidance document "Piling and Penetrative Ground Improvement Methods on Land Affected by Contamination: Guidance on Pollution Prevention. National Groundwater & Contaminated Land Centre report NC/99/73".

Waste

The CLAIRE Definition of Waste: Development Industry Code of Practice (version 2) provides operators with a framework for determining whether or not excavated material arising from site during remediation and/or land development works are waste or have ceased to be waste. Under the Code of Practice:

- excavated materials that are recovered via a treatment operation can be re-used on-site providing they are treated to a standard such that they are fit for purpose and unlikely to cause pollution
- treated materials can be transferred between sites as part of a hub and cluster project formally agreed with the EA
- some naturally occurring clean material can be transferred directly between sites.

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically, and that the permitting status of any proposed on site operations are clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

The Environment Agency recommends that developers should refer to:

- the Position statement on the Definition of Waste: Development Industry Code of Practice and;
- The [Environmental regulations](https://www.gov.uk/government/topics/environmental-regulations) page on GOV.UK

Disposal of soils

Contaminated soil that is, or must be disposed of, is waste. Therefore, its handling, transport, treatment and disposal is subject to waste management legislation, which includes:

- Duty of Care Regulations 1991
- Hazardous Waste (England and Wales) Regulations 2005
- Environmental Permitting (England and Wales) Regulations 2010
- The Waste (England and Wales) Regulations 2011

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically in line with British Standard BS EN 14899:2005 'Characterization of Waste - Sampling of Waste Materials - Framework

for the Preparation and Application of a Sampling Plan' and that the permitting status of any proposed treatment or disposal activity is clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

If the total quantity of waste material to be produced at or taken off site is hazardous waste and is 500kg or greater in any 12 month period the developer will need to register with us as a hazardous waste producer.

Above ground storage of oils, fuels or chemicals and pollution management plan

Any facilities for the storage of oils, fuels or chemicals shall be provided with secondary containment that is impermeable to both the oil, fuel or chemical and water, for example a bund, details of which shall be submitted to the local planning authority for approval. The minimum volume of the secondary containment should be at least equivalent to the capacity of the tank plus 10%. If there is more than one tank in the secondary containment the capacity of the containment should be at least the capacity of the largest tank plus 10% or 25% of the total tank capacity, whichever is greatest.

All fill points, vents, gauges and sight gauge must be located within the secondary containment. The secondary containment shall have no opening used to drain the system. Associated above ground pipework should be protected from accidental damage. Below ground pipework should have no mechanical joints, except at inspection hatches and either leak detection equipment installed or regular leak checks. All fill points and tank vent pipe outlets should be detailed to discharge downwards into the bund.

Flood Risk Activity Permit

The Environmental Permitting (England and Wales) Regulations 2016 require a permit to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culvert (16 metres if tidal)
- on or within 16 metres of a sea defence
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in a floodplain more than 8 metres from the river bank, culvert or flood defence structure (16 metres if it's a tidal main river) and you don't already have planning permission.

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03702 422 549 or by emailing enquiries@environment-agency.gov.uk. The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Advice to LPA

Flood Risk

If there were to be a breach in the Thames Tidal Flood Defences during a 0.5% AEP event for the 2115 epoch, the site could face a flood of up to 5.84 mAOD. The ground floor FFLs are approximately 4.84 mAOD which means that there could be a flood depth of 1.00 m.

Flood resistance and resilience

We strongly recommend the use of flood resistance and resilience measures. Physical barriers, raised electrical fittings and special construction materials are just some of the ways you can help reduce flood damage.

To find out which measures will be effective for this development, please contact your building control department. If you'd like to find out more about reducing flood damage, visit the Flood Risk and Coastal Change pages of the planning practice guidance. Further guidance on flood resistance and resilience measures can also be found in:

Government guidance on flood resilient construction

<https://www.gov.uk/government/publications/flood-resilient-construction-of-new-buildings>

CIRIA Code of Practice for property flood resilience

https://www.ciria.org/Research/Projects_underway2/Code_of_Practice_and_guidance_for_property_flood_resilience.aspx

British Standard 85500 – Flood resistant and resilient construction

<https://shop.bsigroup.com/ProductDetail/?pid=000000000030299686>

Flood risk issues not within our direct remit

The following issues are not within our direct remit or expertise, but nevertheless may be important considerations for managing flood risk for this development. Prior to deciding this application we recommend that consideration is given to the issues below. Where necessary, the advice of relevant experts should be sought.

- Adequacy of rescue or evacuation arrangements
- Details and adequacy of an emergency plan
- Provision of and adequacy of a temporary refuge
- Details and adequacy of flood proofing and other building level resistance and resilience measures
- Details and calculations relating to the structural stability of buildings during a flood
- Whether insurance can be gained or not
- Provision of an adequate means of surface water disposal such that flood risk on and off-site isn't increased

Advice to applicant

Competent persons

The proposed development will be acceptable if a planning condition is included requiring the submission of a remediation strategy, carried out by a competent person in line with paragraph 178 of the NPPF. The Planning Practice Guidance defines a "Competent Person (to prepare site investigation information): A person with a recognised relevant qualification, sufficient experience in dealing with the type(s) of pollution or land instability, and membership of a relevant professional organisation."(<http://planningguidance.planningportal.gov.uk/blog/policy/achieving-sustainable-development/annex-2-glossary/>)"

Note to applicant

Planning advice service

Should you wish us to review any technical documents or want further advice to meet the requirements of the conditions recommended, we may do this as part of our charged for planning advice service.

Further engagement will provide you with certainty of our position as to what our response to your planning application will be. It should also result in a better quality and more environmentally sensitive development.

As part of our charged for service we will provide a dedicated project manager to act as a single point of contact to help resolve any problems. We currently charge £100 per hour, plus VAT. We will provide you with an estimated cost for any further discussions or review of documents. The standard terms of our charged for service are available [here](#).

If you would like more information on our planning advice service, including a cost estimate, please contact us at kslplanning@environment-agency.gov.uk.

Note to LPA

Condition Wording

If you wish to amend the wording of our requested conditions or if you wish to merge them with other Local Planning Authority conditions, please contact us to discuss the revised wording.

Decision notice

In accordance with the planning practice guidance ([determining a planning application, paragraph 019](#)), please notify us by email within two weeks of a decision being made or application withdrawn. Please provide us with a URL of the decision

notice, or an electronic copy of the decision notice or outcome.

Should you have any queries regarding this response, please contact me.

Yours sincerely,

Connor Bowman
Sustainable Places Planning Specialist

Mobile +447771861844

E-mail kslplanning@environment-agency.gov.uk