

Kent County Council

Proposed Connection Schedule

21 March 2024

Land at St. Columba's, Gravesend DA12 - S38 Proposed Lighting - Equipment Schedule - R0

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Service Connection Type	Location	Unit Description	Isolator Type	Termination Type
NC01	-19.09	89.23	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 6m Kent County Council specification lighting column with post top mounted CU Phosco P852K 12 R2B NW CB0500 20W 2.50klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC02	14.5	89.24	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 6m Kent County Council specification lighting column with post top mounted CU Phosco P852K 12 R2B NW CB0500 20W 2.50klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC03	44.22	64.91	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 6m Kent County Council specification mid-hinged raise & lower lighting column with post top mounted CU Phosco P852K 12 R2B NW CB0500 20W 2.50klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC04	57.23	79.22	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 6m Kent County Council specification mid-hinged raise & lower lighting column with post top mounted CU Phosco P852K 12 R2B NW CB0500 20W 2.50klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC05	41.29	88.19	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 6m Kent County Council specification lighting column with post top mounted CU Phosco P852K 12 R2B NW CB0500 20W 2.50klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC06	51.25	103.85	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 6m Kent County Council specification mid-hinged raise & lower lighting column with post top mounted CU Phosco P852K 12 R2B NW CB0500 20W 2.50klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC07	69.34	102.05	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 5m Kent County Council specification mid-hinged raise & lower lighting column with post top mounted CU Phosco P852 12 R2B NW CB0200 9W 1.09klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply
NC08	89.68	91.41	Proposed Double Pole DNO Supply Connection	MMA18541/001	Proposed 5m Kent County Council specification mid-hinged raise & lower lighting column with post top mounted CU Phosco P852 12 R2B NW CB0200 9W 1.09klm neutral white (4000k)	DNO Double Pole DNO Isolator	Proposed Double Pole DNO Supply

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.