



Gravesham Borough Council

Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Highways and Transportation

Kroner House
Eurogate Business Park
Ashford
TN24 8XU

Tel: 03000 418181

Date: 15 October 2024

Our Ref: AO

Application - GB/20240554

Location - 1 Russell Road, Gravesend, Kent, DA12 2RT

Proposal - Demolition of existing dwelling and garage and erection of a two-storey building with roof accommodation, containing 1no. 3 bed dwellinghouse, 3no. studio apartments and 3no. one bed apartments with associated access, private and communal amenity space, refuse and cycle storage.

Thank you for your consultation in relation to the above planning application. I have the following comments to make with respect to highway matters :-

The proposal will result in 1 x 3 bed dwelling and 6 x 1 bed/studio apartments. In line with Kent Residential Parking Standards 2 spaces are to be provided and allocated to the occupants on the 3 bed dwelling, they will be accessed via the existing access that is proposed to be widened. An EV charging unit will need to be provided for the 3 bed dwelling.

No parking will be provided for the 1 bed apartments, the development is located in a highly sustainable location with nearby facilities and local transport links. As such, I consider the nil provision of vehicle parking for the proposed apartments to be acceptable. I am pleased to note that secure, covered cycle storage is to be provided for 6 cycles, which is in accordance with the requirements of Kent Residential Parking Standards (IGN3).

The submitted Highways Technical Note includes a parking survey, carried out on local roads within a 200m walking radius of the site, that demonstrated any additional parking associated with this proposal could be accommodated within available on street parking.

I am satisfied that the trip generation data is robust, it is unlikely that these proposals will result in a significant number of additional trips on the highways and are therefore acceptable.

I refer to the above planning application and confirm that provided the following requirements are secured by condition or planning obligation, then I would raise no objection on behalf of the local highway authority:-

- Provision and permanent retention of the vehicle parking spaces shown on the submitted plans prior to the use of the site commencing.

- Provision and permanent retention of the cycle parking facilities shown on the submitted plans prior to the use of the site commencing.
- Provision and permanent retention of electric vehicle charging facilities for the 3 bed dwelling, prior to the use of the site commencing in accordance with details to be submitted to and approved by the Local Planning Authority.
- Submission of a Construction Management Plan before the commencement of any development on site to include the following:
 - (a) Routing of construction and delivery vehicles to / from site.
 - (b) Parking and turning areas for construction and delivery vehicles and site personnel, which may require supporting vehicle tracking/swept paths.
 - (c) Timing of deliveries, avoiding network and school peaks where possible.
 - (d) Provision of wheel washing facilities.
 - (e) Measures to prevent the discharge of surface water onto the highway.
 - (f) Temporary traffic management /signage.

All Electric Vehicle chargers provided for homeowners in residential developments must be provided to Mode 3 standard (providing a 7kw output) and SMART (enabling Wifi connection). Approved models are shown on the Office for Low Emission Vehicles Homecharge Scheme approved chargepoint model list: <https://www.gov.uk/government/publications/electric-vehicle-homecharge-scheme-approved-chargepoint-model-list>

Planning permission does not convey any approval for construction of the required vehicular crossing, or any other works within the highway for which a statutory licence must be obtained. Applicants should contact Kent County Council - Highways and Transportation (web: www.kent.gov.uk/roads_and_transport.aspx or telephone: 03000 418181) in order to obtain the necessary Application Pack.

It is important to note that Local Planning Authority (LPA) permission does not convey any approval to carry out works on or affecting the public highway.

Any changes to or affecting the public highway in Kent require the formal agreement of the Highway Authority, Kent County Council (KCC), and it should not be assumed that this will be a given because LPA planning permission has been granted.

For this reason, anyone considering works which may affect the public highway, including any highway-owned street furniture or landscape assets such as grass, shrubs and trees, is advised to engage with KCC Highways and Transportation at an early stage in the design process.

Across the county there are pieces of land next to private homes and gardens and near the highway that do not look like roads or pavements but are actually part of the public highway.

Some of this highway land is owned by Kent County Council whilst some is owned by third party owners. Irrespective of the ownership, this land may have 'highway rights' over the topsoil.

Works on private land may also affect the public highway. These include works to cellars, to retaining walls which support the highway or land above the highway, and to balconies, signs

or other structures which project over the highway. Such works also require the approval of the Highway Authority.

Kent County Council has now introduced a pre-application advice service in addition to a full formal technical approval process for new or altered highway assets, with the aim of improving future maintainability. Further details are available on our website below:

<https://www.kent.gov.uk/roads-and-travel/highway-permits-and-licences/highways-permissions-and-technical-guidance>.

This process applies to all development works affecting the public highway other than applications for vehicle crossings, which are covered by a separate approval process. Further details on this are available on our website below:

<https://www.kent.gov.uk/roads-and-travel/highway-permits-and-licences/apply-for-a-dropped-kerb/dropped-kerb-contractor-information>

Once planning approval for any development has been granted by the LPA, it is the responsibility of the applicant to ensure that before development commences, all necessary highway approvals and consents have been obtained, and that the limits of the highway boundary have been clearly established, since failure to do so may result in enforcement action being taken by the Highway Authority.

The applicant must also ensure that the details shown on the approved plans agree in every aspect with those approved under the relevant legislation and common law. It is therefore important for the applicant to contact KCC Highways and Transportation to progress this aspect of the works prior to commencement on site.

Further guidance for applicants, including information about how to clarify the highway boundary and links to application forms for vehicular crossings and other highway matters, may be found on Kent County Council's website:

<https://www.kent.gov.uk/roads-and-travel/highway-permits-and-licences/highways-permissions-and-technical-guidance>. Alternatively, KCC Highways and Transportation may be contacted by telephone: 03000 418181.

Yours faithfully

Director of Highways & Transportation

*This is a statutory technical response on behalf of KCC as Highway Authority. If you wish to make representations in relation to highways matters associated with the planning application under consideration, please make these directly to the Planning Authority.