

Alison Webster
Gravesham Borough Council
Sent via email

Our ref: KT/2024/131681/01-L01
Your ref: 20240402
Date: 04 June 2024

Dear Alison Webster

Demolition of existing buildings and erection of retirement living apartments (use class C3), together with the extension of the existing chapel and the provision of associated communal facilities and external amenity space, lodge keepers and guest accommodation, back-of-house facilities, parking, bicycle/mobility scooter parking, and associated works including the creation of a secondary, emergency access from college road.

Huggens College, College Road, Northfleet, Gravesend, Kent, DA11 9DL

Thank you for consulting us on the above application.

Environment Agency Position

We have **no objections** and consider that planning permission could be granted to the proposed development as submitted if the following **planning conditions** are included as set out below. Without these conditions, the proposed development on this site poses an unacceptable risk to the environment and we would object to the application.

The proposed development is situated upon Boyn Hill Gravel Member overlying Chalk bedrock. Groundwater is particularly sensitive in this location because the proposed development site is within source protection zone 2 and is located upon a secondary aquifer A (Boyn Hill Gravel Member) and a principal aquifer (Chalk).

Land affected by contamination

Condition 1

No development approved by this planning permission shall commence until a strategy to deal with the potential risks associated with any contamination of the site has been submitted to, and approved in writing by, the Local Planning Authority. This strategy will include the following components:

1. A preliminary risk assessment which has identified:
 - all previous uses;
 - potential contaminants associated with those uses;
 - a conceptual model of the site indicating sources, pathways and receptors;
 - and
 - potentially unacceptable risks arising from contamination at the site.

2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. The results of the site investigation and the detailed risk assessment referred to in (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the remediation strategy in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the written consent of the local planning authority. The scheme shall be implemented as approved.

Reason

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution in line with paragraph 180 of the National Planning Policy Framework.

Condition 2

Prior to any part of the permitted development being occupied a verification report demonstrating the completion of works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to, and approved in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met.

Reason

To ensure that the site does not pose any further risk to human health or the water environment by demonstrating that the requirements of the approved verification plan have been met and that remediation of the site is complete. This is in line with paragraph 180 of the National Planning Policy Framework.

Condition 3

If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until a remediation strategy detailing how this contamination will be dealt with has been submitted to and approved in writing by the Local Planning Authority. The remediation strategy shall be implemented as approved.

Reason

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution from previously unidentified contamination sources at the development site in line with paragraph 180 of the National Planning Policy Framework.

Piling

Condition 4

Piling or any other foundation designs using penetrative methods shall not be permitted other than with the express written consent of the Local Planning Authority,

which may be given for those parts of the site where it has been demonstrated by a piling risk assessment that there is no resultant unacceptable risk to groundwater. The development shall be carried out in accordance with the approved details.

Reason

To ensure that the development does not contribute to, or is not put at unacceptable risk from, or adversely affected by, unacceptable levels of water pollution caused by mobilised contaminants in line with paragraph 180 of the National Planning Policy Framework.

Piling Informative 1

Piling can result in risks to groundwater quality by mobilising contamination when boring through different bedrock layers and creating preferential pathways. Thus it should be demonstrated that any proposed piling will not result in contamination of groundwater. If Piling is proposed, a Piling Risk Assessment must be submitted, written in accordance with EA guidance document “Piling and Penetrative Ground Improvement Methods on Land Affected by Contamination: Guidance on Pollution Prevention. National Groundwater & Contaminated Land Centre report NC/99/73”.

Waste on-site Informative 2

The CLAIRE Definition of Waste: Development Industry Code of Practice (DoWCoP, version 2) provides operators with a framework for determining whether or not excavated material arising from site during remediation and/or land development works are waste or have ceased to be waste. Under the Code of Practice:

- excavated materials that are recovered via a treatment operation can be re-used on-site providing they are treated to a standard such that they are fit for purpose and unlikely to cause pollution
- treated materials can be transferred between sites as part of a hub and cluster project formally agreed with the Environment Agency
- some naturally occurring clean material can be transferred directly between sites.

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically, and that the permitting status of any proposed on site operations are clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

It should be noted that re-use of historic landfill materials (including capping materials) is not covered under DoWCoP.

The Environment Agency recommends that developers should refer to:

- the Position statement on the Definition of Waste: Development Industry Code of Practice and;
- The [Environmental regulations](#) page on GOV.UK

Waste Informative 3

Contaminated soil that is, or must be disposed of, is waste. Therefore, its handling, transport, treatment and disposal is subject to waste management legislation, which includes:

- Duty of Care Regulations 1991

- Hazardous Waste (England and Wales) Regulations 2005
- Environmental Permitting (England and Wales) Regulations 2010
- The Waste (England and Wales) Regulations 2011

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically in line with British Standard BS EN 14899:2005 'Characterization of Waste - Sampling of Waste Materials - Framework for the Preparation and Application of a Sampling Plan' and that the permitting status of any proposed treatment or disposal activity is clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays. If the total quantity of waste material to be produced at or taken off site is hazardous waste and is 500kg or greater in any 12 month period the developer will need to register with us as a hazardous waste producer.

Drainage

We have reviewed the Flood Risk Assessment and Drainage Report produced by AFP (Ref: 23/0538, dated March 2024) and understand that surface water is to be discharged to ground via multiple Sustainable Drainage System features, including shallow soakaways, and that foul water is to be discharged via mains sewer. This is considered acceptable from a groundwater protection perspective. However, should these plans change in the future, we would wish to be consulted further.

Drainage Informative 4

Only clean uncontaminated water should drain to the surface water system. Roof drainage shall drain directly to the surface water system (entering after the pollution prevention measures). Appropriate pollution control methods (such as trapped gullies and interceptors) should be used for drainage from access roads and car parking areas to prevent hydrocarbons from entering the surface water system. There should be no discharge into land impacted by contamination or land previously identified as being contaminated. There should be no discharge to made ground. There must be no direct discharge to groundwater, a controlled water.

Please do not hesitate to contact us should you require any further information.

Yours sincerely

Ms Laura Edwards

Planning Advisor

Direct e-mail KSLPLANNING@environment-agency.gov.uk