GRIDLINES FOR EXTERNAL WORKS NOT SHOWN AT THIS STAGE TO BE CONFIRMED BY ARCHITECT

EXISTING SERVICES TO BE CLEARLY MARKED OUT/DIVERTED PRIOR TO THE COMMENCEMENT OF ANY PILING WORKS

SOA SOB SOC SOD SOE SOF SO3

HATCHING DENOTES EXISTING FLOOD DEFENCE WALL TO REMAIN

HATCHING DENOTES EXISTING BUILDING STRUCTURE TO REMAIN

DASHED LINE DENOTES OUTLINE OF BUILDING ABOVE

500x500 RC GROUND BEAM

PC2

PC3

HATCHING DENOTES EXISTING STAIR STRUCTURE TO BE DEMOLISHED

500x600 RC GROUND BEAM

Monitoring Well

MIN. 25mm COMPRESSIBLE FILLER BETWEEN PROPOSED FOUNDATIONS AND EXISTING FLOOD DEFENCE WALL

HATCHING DENOTES PORTION OF EXISTING FLOOD DEFENCE WALL TO BE DEMOLISHED

MIN. 25mm COMPRESSIBLE FILLER BETWEEN PROPOSED FOUNDATIONS AND EXISTING WALL FINISHES


AREA OF ENABLING WORKS RETAINING WALLS

MIN. 25mm COMPRESSIBLE FILLER BETWEEN PROPOSED FOUNDATIONS

(Typ. U.N.O)

1 FOUNDATION GENERAL ARRANGEMENT

1 : 50



NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECT'S AND ENGINEER'S DRAWINGS AND THE SPECIFICATION.
2. ALL WORKMANSHIP AND MATERIALS ARE TO COMPLY WITH THE SPECIFICATION, BUILDING REGULATIONS, RELEVANT BRITISH STANDARD AND MANUFACTURERS RECOMMENDATIONS.
3. THIS DRAWING IS NOT TO BE SCALED. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE. ALL LEVELS ARE IN METRES.
4. ALL DIMENSIONS AND SETTING OUT ARE TO BE CHECKED ON SITE AND DISCREPANCIES ARE TO BE REPORTED TO THE CONTRACT ADMINISTRATOR.
5. FOR GENERAL NOTES REFER TO DRAWING NUMBER 10342643-HDR-XX-XX-DR-S-02150
6. ENABLING AND TEMPORARY RETAINING WORKS TO CONTRACTOR DESIGN
7. PILING PLATFORM LEVEL / TOF ASSUMED +5.700mOD
8. 150mm CONCRETE TO FALLS AT FOUNDATION LEVEL FOR SURFACE WATER FROM DECK
9. BURIED STEEL TO BE ENCASED IN CONCRETE
10. EXPOSED STEEL TO BE TREATED FOR MARINE DRY/WET ENVIRONMENT
11. FIRE RATING TBC BY FIRE CONSULTANT
12. PODIUM BUILD-UP 50mm PAVERS ON PEDESTALS WITH WATERPROOF MEMBRANE
13. GULLIES IN METAL DECK FOR SURFACE WATER TO DRAIN TO FOUNDATION LEVEL TBC
14. STAIRS TO BE CORDECK VOID FORMER
15. SERVICES TO BE SCANNED AND DIVERETED WHERE REQUIRED BY THE CONTRACTOR

Rev	Tech	Date	Description
P2	KS	05/06/2025	STAGE 4 ISSUE
P1	KS	09/05/2025	STAGE 4 ISSUE

HDR

Blackfriars Office
240 Blackfriars Road
London
SE1 8NW
United Kingdom

T: +44 (0)20 7429 3333
hdrinc.com/follow-us
www.hdrinc.com

Client

PORT OF LONDON AUTHORITY

Project Title

PORT CONTROL CENTRE GRAVESEND
PORT OF LONDON AUTHORITY

Drawing Title

PROPOSED EXTERNAL WORKS LAYOUT
FOUNDATION GENERAL ARRANGEMENT

HDR Project No.	Drawing Status	Purpose of Issue
10342643	S4	STAGE 4

First Issue Date	Drawn By	Scale	Checked
JUN' 25	KS	1 : 50 @ A1	PW

Drawing Number	Rev.
PCC-HDR-XX-ZZ-DR-S-02111	P2