

20220311 Meadow Cottage School Lane Higham Rochester Kent ME3 7JG

Environment Agency 9 May 2022

I have had a look at this application and it appears that the applicant intends to install a WC into the garage. There is nothing to say how they will discharge the foul water though.

The site overlays a Principal aquifer and is wholly in Source Protection Zone 2 and partly in 1 as well, and so if they do not intend to connect to mains drainage, we will need to know what they intend to do instead.

Without this information we will object to this application.

Don't hesitate to contact us if you need any further information.