



Kent Fire &
Rescue Service

together

To
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Contact
Fire Engineering Team
Email
FET@kent.fire-uk.org

Our ref
CAS-369927
CAS-346048

Your ref
20260131

Date
22 September 2026

FAO: Lisa Fisher

Dear Lisa,

County of Kent Act 1981 Section 53

Re: Site Of Former Police Station, 133 Windmill Street, Gravesend, Kent, DA12 1DB.

Thank you for your follow up letter dated 2 September 2026. Following my updated assessment of Fire and Rescue Service emergency access provisions for application ref; 20260131, I have the following observations.

The most recent amendments to the Site Plan (Drawing 20085GD_PL102, Rev P2) do not appear to have an impact on the previous comments made within our letter dated 25 February 2026 as dry riser 3 still appears to be in excess of 18m and I am not entirely confident this would be visible from a parked location. Therefore our original letter (CAS-346048) remains valid and we have no further comments at this stage.

Yours sincerely,

Fire Engineering Team

Scan me to subscribe for more building safety information, tips and advice, or to give us feedback on a service provided by our Building Safety Team

