

Thu 16/06/2022 09:17

From: Pete Wright

RE: 20220425 and 20220426 Prepworld, Unit K, Springhead Enterprise Park

To: Joyce, Kelly <kelly.joyce@gravesham.gov.uk>

Hi Kelly,

Thanks for email;-understood.

I've spoken with the sign manufacturer who have confirmed the following:

- ❖ The building mounted illuminated sign (South East elevation) will have an illuminance level not exceeding 600Cdm^2 . They will test the completed sign prior to installation and ensure this is the case.
- ❖ The two totem signs will be circa 200Cdm^2 . These will be initially installed as non-illuminated to determine if vehicle headlights and the estate street lighting is sufficient. If not then ground mounted LED up lights will be added at circa 200Cdm^2
- ❖ All installed sign lighting will have a time clock fitted

Thank you for the notes re the totem signs being placed outside the site. I have passed this to the applicant so they can engage with KCC and GBC to seek the necessary permissions.

Regards,

Pete