



Head of Planning & Regeneration Services
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Your ref
20220135

Our ref
DSA000015444

Date
27/09/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Revised plans Application for variation of condition 2 attached to planning permission reference no. 202106712 Application for the variation of condition 2 attached to planning permission reference number 20130801 to provide social housing to ex service personnel to provide a mix of 3 bedroom 2 storey houses, single bedroom flats, 2 bedroom flats, 2 bedroom cottages and a 3 bedroom maisonette for warden, car parking and cycle storage; to allow a reconfiguration of the Blocks A, B, F and G, car parking layout and refuse and cycle store locations.

Site: 20220135: - Elizabeth Huggins Cottages, Cross Lane West, Gravesend, Kent, DA11 7LD.

Thank you for your letter dated 23/08/2022.

The attached plan shows that the proposed development will lie close to an existing public foul sewer, which will not be acceptable to Southern Water. The exact position of the public apparatus must be determined on site by the applicant before the layout of the proposed development is finalised.

It might be possible to divert the sewer, so long as this would result in no unacceptable loss of hydraulic capacity, and the work was carried out at the developer's expense to the satisfaction of Southern Water under the relevant statutory provisions.

- The 150 mm public foul sewer requires a clearance of 3 metres on either side of the gravity sewer to protect it from construction works and to allow for future access for maintenance.

- No development or tree planting should be carried out within 3 metres of the external edge of the public gravity sewer without consent from Southern Water.

- No soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public sewer.

- All existing infrastructure should be protected during the course of construction works.

Please refer to: southernwater.co.uk/media/3011/stand-off-distances.pdf

Alternatively, the applicant may wish to amend the site layout, or combine a diversion with amendment of the site layout. If the applicant would prefer to advance these options, items above also apply.

Furthermore, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission; for example, the developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to divert the public sewers, prior to the commencement of the development.

Our initial investigations indicate that Southern Water can provide foul sewage disposal to service the proposed development. Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development