

Environmental Protection COMMENTS

Case Number	20211541
Case Officer	Mr Richard Hart
Address	Metropolitan Police Specialist Training Centre, Mark Lane, Gravesend, Kent, DA12 2HN

Proposal	Erection of a new concrete live fire skills house training building (plus abseil frame) with new ancillary support building and associated works.
Consultation Expiry Date	13 January 2022
Date of Response	

The following to be considered:

Drainage/sewerage informative

The foul sewage shall be removed by means of the mains drainage system and not by the use of non-mains sewerage systems, unless connection to the drainage system is not reasonably practicable. If foul sewage is to be removed using non-mains sewerage systems, a sewage treatment plant or septic tank system will be considered in preference to a cesspool. Such a system may require the prior consent of the Environment Agency under the terms of the Water Resources Act 1991. Applicants are therefore advised to discuss their requirements with the Environment Agency at the earliest opportunity. It should be ensured that the septic tank or cesspool is of adequate capacity to serve the proposed development and suitable access and hardstanding area shall be maintained to it on site.

Code of Practice on Construction and Demolition

Please apply

Watching Brief

The applicant shall undertake a watching brief during construction in case any contamination issue is encountered. If during development any contamination is found, the local planning authority should be informed as soon as practical and the work shall not continue until written agreement is provided by the LPA as to the appropriate measures to be taken to resolve the matter and they are satisfied that those measures have been carried out.