



Katherine Parkin
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Flood and Water Management
Invicta House
Maidstone
Kent
ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: GBC/2025/103713
Date: 28 May 2025

Application No: 20241011

Location: Land And Buildings At Seacon Site, Tower Wharf, Lower Road, Northfleet
Gravesend

Proposal: Extension of existing storage warehouse to provide a bagging and packaging facility for aggregates and cementitious products, incorporating extensions to both sides, a new warehouse section to the south and silos to the side.

Thank you for your consultation on the above referenced planning application.

Kent County Council as Lead Local Flood Authority have reviewed additional information provided by the applicant and have the following comments:

- Additional hydraulic calculations have been provided displaying amended CV values and utilising modified rainfall intensities as requested.

Kent County Council as Lead Local Flood Authority would see no further reason to object to the application, however would note the following advisory comments:

- We note that Southern Water currently have object to the proposals and whilst we accept the reuse of this connection with a reduced outfall rate, the LPA should ensure themselves that Southern Water are accepting of the principles, and thus, therefore that the proposals can be drained and shall not increase the risk of flooding.

Subject to the LPA being satisfied, we would recommend the following conditions:

Condition:

Development shall not begin in any phase until a detailed sustainable surface water drainage scheme for the site has been submitted to (and approved in writing by) the local planning authority. The detailed drainage scheme shall be based upon the Drainage Strategy Plan prepared by Leimen LTD (Apr 2025). The submitted scheme shall demonstrate compliance with the required technical standards at the time of submission and shall demonstrate that the surface water generated by this development (for all rainfall durations and intensities up to and including the climate change adjusted critical 100 year storm) can be accommodated and disposed of without increase to flood

risk on or off-site.

The drainage scheme shall also demonstrate (with reference to published guidance):

- that silt and pollutants resulting from the site use can be adequately managed to ensure there is no pollution risk to receiving waters.
- appropriate operational, maintenance and access requirements for each drainage feature or SuDS component are adequately considered, including any proposed arrangements for future adoption by any public body or statutory undertaker.

The drainage scheme shall be implemented in accordance with the approved details.

Reason:

To ensure the development is served by satisfactory arrangements for the disposal of surface water and to ensure that the development does not exacerbate the risk of on/off site flooding. These details and accompanying calculations are required prior to the commencement of the development as they form an intrinsic part of the proposal, the approval of which cannot be disaggregated from the carrying out of the rest of the development.

Condition:

No building on any phase (or within an agreed implementation schedule) of the development hereby permitted shall be occupied until a Verification Report, pertaining to the surface water drainage system and prepared by a suitably competent person, has been submitted to and approved by the Local Planning Authority. The Report shall demonstrate that the drainage system constructed is consistent with that which was approved. The Report shall contain information and evidence (including photographs) of details and locations of inlets, outlets and control structures; landscape plans; full as built drawings; information pertinent to the installation of those items identified on the critical drainage assets drawing; and, the submission of an operation and maintenance manual for the sustainable drainage scheme as constructed.

Reason:

To ensure that flood risks from development to the future users of the land and neighbouring land are minimised, together with those risks to controlled waters, property and ecological systems, and to ensure that the development as constructed is compliant with and subsequently maintained pursuant to the requirements of paragraph 182 of the National Planning Policy Framework.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

Euan Allen

Graduate Flood Risk Officer
Flood and Water Management