



Amanda Grout
Gravesham Borough Council
Civic Centre
Windmill Street
Gravesend
Kent
DA12 1AU

Flood and Water Management

Invicta House
Maidstone
Kent
ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: GBC/2022/091836
Date: 21 November 2022

Application No: 20220839

Location: Cobham Lodge , Valley Drive, Gravesend, Kent DA12 5UE

Proposal: Conversion of existing house to 10no. flats including side and rear extension and loft conversion. Conversion of rear annex building to 2no. dwelling houses including proposed new dormers. Construction of new apartment building to form 11no. new apartments. Construction of 8no. semidetached and 1no. detached houses and associated development.

Thank you for your consultation on the above referenced planning application.

Kent County Council as Lead Local Flood Authority have reviewed the Surface Water Management Strategy prepared by Herrington Consulting Ltd. (10/11/22). We understand that surface water from the site will be collected via permeable paving and conveyed to a soakaway, both of which will infiltrate at 0.1 m/hr. We have no objection in principal to this proposal.

Should the Local Planning Authority be minded to grant planning permission for the proposed development, the LLFA would request for the following conditions to be attached:

Condition:

No development (except for demolition/ site clearance shall begin in any until a detailed sustainable surface water drainage scheme for the site has been submitted to (and approved in writing by) the local planning authority. The detailed drainage scheme shall be based upon the Surface Water Management Strategy prepared by Herrington Consulting Ltd. (10/11/22) and shall demonstrate that the surface water generated by this development (for all rainfall durations and intensities up to and including the climate change adjusted critical 100 year storm) can be accommodated and disposed of within the curtilage of the site without increase to flood risk on or off-site.

The drainage scheme shall also demonstrate (with reference to published guidance):

- that silt and pollutants resulting from the site use can be adequately managed to ensure there is no pollution risk to receiving waters.
- appropriate operational, maintenance and access requirements for each drainage feature or SuDS component are adequately considered, including any proposed arrangements for future adoption by any public body or statutory undertaker.

The drainage scheme shall be implemented in accordance with the approved details.

Reason:

To ensure the development is served by satisfactory arrangements for the disposal of surface water and to ensure that the development does not exacerbate the risk of on/off site flooding. These details and accompanying calculations are required prior to the commencement of the development as they form an intrinsic part of the proposal, the approval of which cannot be disaggregated from the carrying out of the rest of the development.

Condition:

No building on any phase (or within an agreed implementation schedule) of the development hereby permitted shall be occupied until a Verification Report, pertaining to the surface water drainage system and prepared by a suitably competent person, has been submitted to and approved by the Local Planning Authority. The Report shall demonstrate that the drainage system constructed is consistent with that which was approved. The Report shall contain information and evidence (including photographs) of details and locations of inlets, outlets and control structures; landscape plans; full as built drawings; information pertinent to the installation of those items identified on the critical drainage assets drawing; and, the submission of an operation and maintenance manual for the sustainable drainage scheme as constructed.

Reason:

To ensure that flood risks from development to the future users of the land and neighbouring land are minimised, together with those risks to controlled waters, property and ecological systems, and to ensure that the development as constructed is compliant with and subsequently maintained pursuant to the requirements of paragraph 165 of the National Planning Policy Framework.

Condition:

Where infiltration is to be used to manage the surface water from the development hereby permitted, it will only be allowed within those parts of the site where information is submitted to demonstrate to the Local Planning Authority's satisfaction that there is no resultant unacceptable risk to controlled waters and/or ground stability. The development shall only then be carried out in accordance with the approved details.

Reason:

To protect vulnerable groundwater resources and ensure compliance with the National Planning Policy Framework.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

Gideon Miller

Graduate Flood Risk Officer
Flood and Water Management